

ADDRESS : 116 APPLEJACK LN SUBDIV: BENTLEY WOODS  
CONTRACTOR : BYRD JOHN LEWIS PHONE : (919) 894-4509  
OWNER : BYRD JOHN L. #4 PHONE :  
PARCEL : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB  
LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431

5-1 AP

----- COMMENTS AND NOTES -----

ADDRESS : 215 HOLLY OAK CIR  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : WOODSHIRE PARTNERS LLC #53  
PARCEL : 01-0536-02- -0028- -53-  
APPL NUMBER: 06-50014688 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : FOREST OAKS LOT 53. HWY 27W LEFT ONTO  
NURSERY RD TURN LEFT ON LEMEUL BLACK  
LEFT INTO FOREST OAKS RIGHT ON HOLLY  
OAK LOT IN CUL DE SAC. -A.DRIGGERS

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE : (919) 481-0503  
PHONE : (910) 481-0503

STRUCTURE: 000 000 46X38 3BR SFD  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001357417
	2/20/07	AP	t-pole # 10065 . ce
B111 01	2/23/07	KS	R*BLDG SLAB INSP VRU #: 001358925
	2/23/07	AP	
H824 01	3/27/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001380138
	3/27/07	AP	
R425 01	4/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001395797
	4/24/07	DA	1. window by back door to be tempered 2. outlets missing at living room pass through area and small wall by laundry 3. boots missing
R425 02	4/25/07	MR	FOUR TRADE ROUGH IN VRU #: 001397054
	4/25/07	AE	check boots on insul.
I129 01	5/01/07		R*INSULATION INSPECTION VRU #: 001400184

Handwritten initials: MR, AE, DP, JH

----- COMMENTS AND NOTES -----

-----

ADDRESS . : 116 APPLEJACK LN SUBDIV: BENTLEY WOODS  
 CONTRACTOR : BYRD JOHN LEWIS PHONE : (919) 894-4509  
 OWNER . . : BYRD JOHN L. #4 PHONE :  
 PARCEL . . : 02-1526- - -0100- -05-  
 APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
 RIGHT ON RED HILL CHURCH RD GO TO NEXT  
 LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
 TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
 JB  
 LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

-----

**STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY**  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
A814 01	5/15/07	TI	ADDRESS CONFIRMATION VRU #: 001409358
B103 01	5/15/07 <i>S-15</i>	TI <i>DA</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 116 APPLEJACK LN SUBDIV: BENTLEY WOODS  
CONTRACTOR : BYRD JOHN LEWIS PHONE : (919) 894-4509  
OWNER . . : BYRD JOHN L. #4 PHONE :  
PARCEL . . : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB  
LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL  
-----

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287

5-18 AP

----- COMMENTS AND NOTES -----

ADDRESS : 116 APPLEJACK LN  
CONTRACTOR : BYRD JOHN LEWIS  
OWNER : BYRD JOHN L. #4  
PARCEL : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENTLEY WOODS  
PHONE : (919) 894-4509  
PHONE :

DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	TI	R*OPEN FLOOR VRU #: 001413327
	<u>5-22-</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

-----  
ADDRESS . . : 116 APPLEJACK LN SUBDIV: BENTLEY WOODS  
CONTRACTOR : BYRD JOHN LEWIS PHONE : (919) 894-4509  
OWNER . . . : BYRD JOHN L. #4 PHONE :  
PARCEL . . . : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL  
-----

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	KS	R*OPEN FLOOR VRU #: 001413327
	5/22/07	AP	
R425 01	7/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001454073
	7/26/07	CA	
R425 02	7/30/07	TI	FOUR TRADE ROUGH IN VRU #: 001455286

738 DA

----- COMMENTS AND NOTES -----

**Violation Notice**  
**Do Not Remove**

**Harnett County Inspection Department**  
**102 East Front St P.O. Box 65**  
**Lillington, NC 27546**  
**Phone (910) 893-4876 Fax (910) 893-2793**

App #05-50011854

1. All plumbing shall be protected with plates that go 2 inches above and below top and bottom plate.
2. Tub traps shall be rat proffed with metal collar attached to surrounding material.
3. Install midstory guides on all pipes 2 inches and smaller
4. Smoke detectors shall be wired with 14.3
5. All home runs supplying 14-2 lighting or receptacle circuits shall be run in similar wiring.
6. Tie back from rafters or install hurricane ties.
7. Add cleanout brought up to grade.
8. Need receptacle accessible from grade at front and rear of house.
9. Fire caulk all penetrations

Ok to side. Do not insulate

Code Enforcement Official

Signature Ken Slattum 910-984-4766 \_\_\_\_\_

ADDRESS : 116 APPLEJACK LN  
CONTRACTOR : BYRD JOHN LEWIS  
OWNER : BYRD JOHN L. #4  
PARCEL : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENTLEY WOODS  
PHONE : (919) 894-4509  
PHONE :

DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	KS	R*OPEN FLOOR VRU #: 001413327
	5/22/07	AP	
R425 01	7/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001454073
	7/26/07	CA	
R425 02	7/30/07	KS	FOUR TRADE ROUGH IN VRU #: 001455286
	7/30/07	DA	1. All plumbing shall be protected with plates that go 2 inches above and below top and bottom plate. 2. Tub traps shall be rat proffed with metal collar attached to surrounding material. 3. Install midstory guides on all pipes 2 inches and smaller 4. Smoke detectors shall be wired with 14.3 5. All home runs supplying 14-2 lighting or receptacle circuits shall be run in similar wiring. 6. Tie back from rafters or install hurricane ties. 7. Add cleanout brought up to grade. 8. Need receptacle accessible from grade at front and rear of house. 9. Fire caulk all penetrations Ok to side. Do not insulate
R425 03	8/01/07	TI	FOUR TRADE ROUGH IN VRU #: 001457886

8-1- AP

----- COMMENTS AND NOTES -----



ADDRESS : 116 APPLEJACK LN  
 CONTRACTOR : BYRD JOHN LEWIS  
 OWNER : BYRD JOHN L. #4  
 PARCEL : 02-1526- - -0100- -05-  
 APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENTLEY WOODS  
 PHONE : (919) 894-4509  
 PHONE :

DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
 RIGHT ON RED HILL CHURCH RD GO TO NEXT  
 LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
 TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
 JB

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	KS	R*OPEN FLOOR VRU #: 001413327
	5/22/07	AP	
R425 01	7/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001454073
	7/26/07	CA	
R425 02	7/30/07	KS	FOUR TRADE ROUGH IN VRU #: 001455286
	7/30/07	DA	1. All plumbing shall be protected with plates that go 2 inches above and below top and bottom plate. 2. Tub traps shall be rat proffed with metal collar attached to surrounding material. 3. Install midstory guides on all pipes 2 inches and smaller 4. Smoke detectors shall be wired with 14.3 5. All home runs supplying 14-2 lighting or receptacle circuits shall be run in similar wiring. 6. Tie back from rafters or install hurricane ties. 7. Add cleanout brought up to grade. 8. Need receptacle accessible from grade at front and rear of house. 9. Fire caulk all penetrations Ok to side. Do not insulate
R425 03	8/01/07	KS	FOUR TRADE ROUGH IN VRU #: 001457886
	8/01/07	AP	
I129 01	8/28/07	TI	R*INSULATION INSPECTION VRU #: 001474980

8-28 AK

COMMENTS AND NOTES

ADDRESS : 116 APPLEJACK LN  
 CONTRACTOR : BYRD JOHN LEWIS  
 OWNER : BYRD JOHN L. #4  
 PARCEL : 02-1526- - -0100- -05-  
 APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
 RIGHT ON RED HILL CHURCH RD GO TO NEXT  
 LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
 TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
 JB

SUBDIV: BENTLEY WOODS  
 PHONE : (919) 894-4509  
 PHONE :

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY  
 FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001412287
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 00140931
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four weeks.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 00140358
	5/17/07	AP	✓116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	KS	R*OPEN FLOOR VRU #: 001413327
	5/22/07	AP	
R425 01	7/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001454073
	7/26/07	CA	
R425 02	7/30/07	KS	FOUR TRADE ROUGH IN VRU #: 001455286
	7/30/07	DA	1. All plumbing shall be protected with plates that go 2 inches above and below top and bottom plate. 2. Tub traps shall be rat proffed with metal collar attached to surrounding material. 3. Install midstory guides on all pipes 2 inches and smaller 4. Smoke detectors shall be wired with 14.3 5. All home runs supplying 14-2 lighting or receptacle circuits shall be run in similar wiring. 6. Tie back from rafters or install hurricane ties. 7. Add cleanout brought up to grade. 8. Need receptacle accessible from grade at front and rear of house. 9. Fire caulk all penetrations Ok to side. Do not insulate
R425 03	8/01/07	KS	FOUR TRADE ROUGH IN VRU #: 001457886
	8/01/07	AP	
I129 01	8/28/07	KS	R*INSULATION INSPECTION VRU #: 001474980
	8/28/07	AP	
H824 01	1/15/08	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001549013
	1/15/08	AP	
R429 01	1/28/08	TI	FOUR TRADE FINAL VRU #: 001551399

1-28-08 DABS

COMMENTS AND NOTES

ADDRESS : 116 APPLEJACK LN  
CONTRACTOR : BYRD JOHN LEWIS  
OWNER : BYRD JOHN L. #4  
PARCEL : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENTLEY WOODS  
PHONE : (919) 894-4509  
PHONE :

DIRECTIONS : TAKE HIGHWAY 27 TO BASS STORE TURN  
RIGHT ON RED HILL CHURCH RD GO TO NEXT  
LEFT ON TO TILGHMAN RD TRUN LEFT AT 559  
TILGHMAN RD ON TO APPLEJACK LANE LOT #4  
JB

\*\*\*\*\*pre# 69544805\*\*\*\*\*

LAND NOTES : LXMN 4/12/05 SPLIT FROM THE 02 PARCEL

STRUCTURE: 000 000 44 X 62 3BDR 59 W/ BREEZE WAY

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00 PROPOSED USE : SFD

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/27/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001398361
	4/27/07	CA	NEED ENGINEERS LETTER ON FOOTING
B101 02	5/01/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001400431
	5/01/07	AP	
B103 01	5/15/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001409341
	5/15/07	DA	Uncover foundation so it can be inspected. We have not allowed foundation to be backfilled for four years.
A814 01	5/15/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001409358
	5/17/07	AP	116 Applejack Ln
B103 02	5/18/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412287
	5/18/07	AP	
B105 01	5/22/07	KS	R*OPEN FLOOR VRU #: 001413327
	5/22/07	AP	
R425 01	7/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001454073
	7/26/07	CA	
R425 02	7/30/07	KS	FOUR TRADE ROUGH IN VRU #: 001455286
	7/30/07	DA	1. All plumbing shall be protected with plates that go 2 inches above and below top and bottom plate. 2. Tub traps shall be rat proffed with metal collar attached to surrounding material. 3. Install midstory guides on all pipes 2 inches and smaller 4. Smoke detectors shall be wired with 14.3 5. All home runs supplying 14-2 lighting or receptacle circuits shall be run in similar wiring. 6. Tie back from rafters or install hurricane ties. 7. Add cleanout brought up to grade. 8. Need receptacle accessible from grade at front and rear of house. 9. Fire caulk all penetrations Ok to side. Do not insulate
R425 03	8/01/07	KS	FOUR TRADE ROUGH IN VRU #: 001457886
	8/01/07	AP	
I129 01	8/28/07	KS	R*INSULATION INSPECTION VRU #: 001474980
	8/28/07	AP	
H824 01	1/15/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001549013
	1/15/08	AP	
R429 01	1/28/08	BS	FOUR TRADE FINAL VRU #: 001551399
	1/28/08	DA	1. All hvac units have improper breaker sizes. 2. Need plastic under house 3. Septic alarm circuit must be seperate from pump circuit. 4. Need a disconnect on water heater or breaker lockout. 5. Missing cover on whirlpool receptacle.

PREPARED 1/28/08, 14:13:53  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 2  
DATE 1/29/08

-----  
ADDRESS : 116 APPLEJACK LN  
CONTRACTOR : BYRD JOHN LEWIS  
OWNER : BYRD JOHN L. #4  
PARCEL : 02-1526- - -0100- -05-  
APPL NUMBER: 05-50011854 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENTLEY WOODS  
PHONE : (919) 894-4509  
PHONE :

-----  
REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS  
-----  
R429 02 1/29/08 TI FOUR TRADE FINAL VRU #: 001553890  
1-29-08 ARB

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SF1

Type of Construction: II

Owner of Building: John Lewis Byrd

Building Address: 116 Apple Jack Ln

Zoning District: \_\_\_\_\_

Zoning Permit No.: 11A

Conditional Use Permit No.: \_\_\_\_\_

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

Envir. C.O. No.: \_\_\_\_\_

Date: 1-29-08

Byrd Smith

Building Official

Zoning Official