

HTE # 0550012040

ORNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

18203

# OPERATIONS PERMIT

Name: (owner) Oak City Homes  New Installation  Septic Tank  Repair

Property Location: SR# 1437 BALLAZO RD  Nitrification Line  Expansion

Subdivision Ballazo Woods Lot # 75 Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Contractor: Tommy Coley Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

**Following are the specifications for the sewage disposal system on above captioned property.**

Type of system:  Conventional  Other POLYSTYRENE AGGREGATE TRENCH SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field	No. of ditches <u>4</u>	exact length of each ditch <u>60</u> ft.	width of ditches <u>3</u> ft.	depth of ditches <u>18-24</u> in.
------------------------------	----------------------------	---	----------------------------------	--------------------------------------

French Drain Required: \_\_\_\_\_ Linear feet

Date: 3/8/06

PERMIT NO. 22063

Inspected by: [Signature]

