

HTE 0550012042

IMPROVEMENT PERMIT

22059

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department." *Re: Oak City Homes*

Name: (owner) BALLARD WOODS LLC New Installation Septic Tank
Property Location: SR# 1437 BALLARD RD Repairs Nitrification Line

Subdivision BALLARD WOODS Lot # 39

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .59 AC

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18 in. *SEE NOTE.*

French Drain Required: _____ Linear feet

Date: 5/27/05
Signed: [Signature] RS (OLIVER TOLKDOFF)
103' Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- * MAINTAIN ALL SETBACKS
- * LOT GRADED AFTER EVALUATION. TRENCHES TO BE 24" DEEP UNDER CURRENT GRADE.
- * CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22059. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Ballard Woods LLC Re: (Oak City Homes) Telephone # 919-833-5526

Address PO Box 6127 RALEIGH NC 27628

Property Location SR# 1437 Road Name BALLARD RD

Subdivision BALLARD WOODS Lot # 39 # Bedrooms Proposed 3 Lot Size .59 AC

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines
 Conventional [] Other _____

[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal


NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 2 Length of lines 150 Ft.

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

 Signature of Authorized Agent for Harnett County

5/24/05
Date