

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 05-500 12171

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949): 360

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-8	GR SL	VFA JL					
		8-18	SBH SL	FR JL					
		18-24	SBH SL	F2 JL					
		28"	Rock	Gravel		28		.3	
		0-8	GR SL	VFA JL					
		8-12	SBH SL	FR SL					
		12-30	SBH SL	F2 JL					
		30"	Rock	Gravel		30"		.3	
		0-10	GR SL	VFA JL					
		10-24	SBH SL	FR JL					
		24-26	SBH SL	F2 JL					
		26"	Rock	Gravel		26		.3	
		0-12	GR SL	VFA JL					
		12-18	SBH SL	FR JL					
		18-26	SBH SL	F2 JL					
		28"	Rock	Gravel		28		.3	

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	GRAV	LPP
Site LTAR	.3	.15

Other Factors (.1946): _____
 Site Classification (.1948): P3
 Evaluated By: JW
 Others Present: SS, K

Meet on site with back hoe for deeper hole

1x400 12" deep


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			
		SICL-SILTY CLAY LOAM		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



< - (1,000.96) E (96.000) N -

NEW CENTURY HOMES LLC.

THE JORDAN *w/Sun Room*
LOT #156 CRESTVIEW
SCALE: 1"=40'

SITE PLAN APPROVAL

DISTRICT RA202 USE SFD


#BEDROOMS 3

05/18/2005 A. Triggus
Date Zoning Administrator

< - N 01° 28' 25" W (358.570') -

289'-0 3/4"

- S 01° 04' 23" E (381.610') ->



Permit Copy

Forest Mt.
Ct.

AL=56°-0' 11/16"
R=50°-0'
Δ=64.2389
AL=21°-0' 5/16"
R=25°-0'
Δ=78.368

- S 88° 55' 37" W (24.100') -