

ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
TENANT, NBR: 2 16873
CONTRACTOR : PHONE :
OWNER : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
PARCEL : 13-0519- - -0078- -06-
APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 2850 SPRING HILL CHURCH RD
TAKE HWY 421, TURN LEFT ON OLD 421,
TURN LEFT ON MCDOUGALD RD, TURN LEFT ON
SPRING HILL CHURCH, LOT IS 2/10 MILE ON
THE LEFT PRUSSELL

LAND NOTES : LXMN 7/07/05 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 60X68 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/28/07 <i>11/28/07</i>	<i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001525807 If there are any questions or concerns I can be reached at 910-893-2252 or 910-814-2192. Port-a-john should be delivered thursday. Temp service pole should be in position. Thank you Elwood Sherman

ES

COMMENTS AND NOTES

ADDRESS . : 2850 SPRING HILL CHURCH RD SUBDIV:
 TENANT, NBR: 2 16873
 CONTRACTOR : PHONE :
 OWNER . . : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
 PARCEL . . : 13-0519- - -0078- -06-
 APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 2850 SPRING HILL CHURCH RD
 TAKE HWY 421, TURN LEFT ON OLD 421,
 TURN LEFT ON MCDUGALD RD, TURN LEFT ON
 SPRING HILL CHURCH, LOT IS 2/10 MILE ON
 THE LEFT PRUSSELL
 PREMISE # 28592667
 LAND NOTES : LXMN 7/07/05 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 60X68 3BR SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/28/07 11/28/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001525807 If there are any questions or concerns I can be reached at 910-893-2252 or 910-814-2192. Port-a-john should be delivered thursday. Temp service pole should be in position. Thank you Elwood Sherman
A814 01	12/07/07 12/06/07	TI CA	ADDRESS CONFIRMATION VRU #: 001531771
B103 01	12/07/07 12/07/07	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001531805
E207 01	12/07/07 12/07/07	FS AP	R*ELEC TEMP SERVICE POLE VRU #: 001531813
A814 02	12/07/07 12/11/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001531789 2850 SPRING HILL CHURCH RD
B105 01	12/11/07 12/11/07	FS AP	R*OPEN FLOOR VRU #: 001532902
B109 01	1/29/08	TI	R*BLDG ROUGH IN > 2500 VRU #: 001553916
E203 01	1/29/08	TI	R*ELEC ROUGH IN > 2500 VRU #: 001553924
M403 01	1/29/08	TI	R*MECH ROUGH IN > 2500 VRU #: 001553932
P303 01	1/29/08	TI	R*PLUMB ROUGH IN > 2500 VRU #: 001553940

COMMENTS AND NOTES

ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
 TENANT, NBR: 2 16873
 CONTRACTOR :
 OWNER . . : SHERMAN ELWOOD & DANA #7 PHONE :
 PARCEL . . : 13-0519- - -0078- -06- PHONE : (910) 893-2252
 APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 2850 SPRING HILL CHURCH RD
 TAKE HWY 421, TURN LEFT ON OLD 421,
 TURN LEFT ON MCDUGALD RD, TURN LEFT ON
 SPRING HILL CHURCH, LOT IS 2/10 MILE ON
 THE LEFT PRUSSELL
 PREMISE # 28592667

LAND NOTES : LXMN 7/07/05 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 60X68 3BR SFD
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/28/07 11/28/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001525807 If there are any questions or concerns I can be reached at 910-893-2252 or 910-814-2192. Port-a-john should be delivered thursday. Temp service pole should be in position. Thank you Elwood Sherman
A814 01	12/07/07 12/06/07	TI CA	ADDRESS CONFIRMATION VRU #: 001531771
B103 01	12/07/07 12/07/07	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001531805
E207 01	12/07/07 12/07/07	FS AP	R*ELEC TEMP SERVICE POLE VRU #: 001531813
A814 02	12/07/07 12/11/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001531789 2850 SPRING HILL CHURCH RD
B105 01	12/11/07 12/11/07	FS AP	R*OPEN FLOOR VRU #: 001532902
B109 01	1/29/08 1/29/08	JH DA	R*BLDG ROUGH IN > 2500 VRU #: 001553916 1 Need 2 studs under lvl to left of garage door. 2 Missing nail guards in garage. 3 Ground all metal boxes with green ground screw. 4 Replace all insulation in garage used for fire stopping. 5 Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6 Rodent proof all holes under tubs & showers. 7 Need to support water lines @ spare bath tub per code. 8 Exhaust fans need to be piped to the outside. 9 Add stud @ end of shower in master bath. 10 Leaks in drain line under house to left of crawl door see Mike.
E203 01	1/29/08 1/29/08	JH DA	R*ELEC ROUGH IN > 2500 VRU #: 001553924 1 Need 2 studs under lvl to left of garage door. 2 Missing nail guards in garage. 3 Ground all metal boxes with green ground screw. 4 Replace all insulation in garage used for fire stopping. 5 Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6 Rodent proof all holes under tubs & showers. 7 Need to support water lines @ spare bath tub per code. 8 Exhaust fans need to be piped to the outside. 9 Add stud @ end of shower in master bath.


ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
TENANT, NBR: 2 16873
CONTRACTOR : PHONE :
OWNER : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
PARCEL : 13-0519- - -0078- -06-
APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M403 01	1/29/08 1/29/08	JH DA	1)Leaks in drain line under house to left of crawl door see Mike. R*MECH ROUGH IN > 2500 VRU #: 001553932 7)Need 2 studs under lvl to left of garage door. 8)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be piped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
P303 01	1/29/08 1/29/08	JH DA	R*PLUMB ROUGH IN > 2500 VRU #: 001553940 7)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be piped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
B109 02	1/31/08	TI AP JH	R*BLDG ROUGH IN > 2500 VRU #: 001555036
E203 02	1/31/08	TI AP JH	R*ELEC ROUGH IN > 2500 VRU #: 001555044
M403 02	1/31/08	TI AP JH	R*MECH ROUGH IN > 2500 VRU #: 001555051
P303 02	1/31/08	TI AP JH	R*PLUMB ROUGH IN > 2500 VRU #: 001555069

COMMENTS AND NOTES

ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
 TENANT, NBR: 2 16873
 CONTRACTOR : PHONE :
 OWNER : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
 PARCEL : 13-0519- - -0078- -06-
 APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M403 01	1/29/08 1/29/08	JH DA	9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike. R*MECH ROUGH IN > 2500 VRU #: 001553932 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
P303 01	1/29/08 1/29/08	JH DA	R*PLUMB ROUGH IN > 2500 VRU #: 001553940 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
B109 02	1/31/08 1/31/08	JH AP	R*BLDG ROUGH IN > 2500 VRU #: 001555036
E203 02	1/31/08 1/31/08	JH AP	R*ELEC ROUGH IN > 2500 VRU #: 001555044
M403 02	1/31/08 1/31/08	JH AP	R*MECH ROUGH IN > 2500 VRU #: 001555051
P303 02	1/31/08 1/31/08	JH AP	R*PLUMB ROUGH IN > 2500 VRU #: 001555069
I129 01	2/05/08	AP	R*INSULATION INSPECTION VRU #: 001557677

2-5-8 AP


COMMENTS AND NOTES

6

ADDRESS . : 2850 SPRING HILL CHURCH RD SUBDIV:
TENANT, NBR: 2 16873
CONTRACTOR : PHONE :
OWNER . . : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
PARCEL . . : 13-0519- - -0078- -06-
APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 2850 SPRING HILL CHURCH RD
TAKE HWY 421, TURN LEFT ON OLD 421,
TURN LEFT ON MCDOUGALD RD, TURN LEFT ON
SPRING HILL CHURCH, LOT IS 2/10 MILE ON
THE LEFT PRUSSELL
PREMISE # 28592667
LAND NOTES : LXMN 7/07/05 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 60X68 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/28/07 11/28/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001525807 If there are any questions or concerns I can be reached at 910-893-2252 or 910-814-2192. Port-a-john should be delivered thursday. Temp service pole should be in position. Thank you Elwood Sherman
A814 01	12/07/07 12/06/07	TI CA	ADDRESS CONFIRMATION VRU #: 001531771
B103 01	12/07/07 12/07/07	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001531805
E207 01	12/07/07 12/07/07	FS AP	R*ELEC TEMP SERVICE POLE VRU #: 001531813
A814 02	12/07/07 12/11/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001531789 2850 SPRING HILL CHURCH RD
B105 01	12/11/07 12/11/07	FS AP	R*OPEN FLOOR VRU #: 001532902
B109 01	1/29/08 1/29/08	JH DA	R*BLDG ROUGH IN > 2500 VRU #: 001553916 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be piped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
E203 01	1/29/08 1/29/08	JH DA	R*ELEC ROUGH IN > 2500 VRU #: 001553924 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be piped to the outside.

ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
 TENANT, NBR: 2 16873
 CONTRACTOR : PHONE :
 OWNER : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
 PARCEL : 13-0519- - -0078- -06-
 APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 2850 SPRING HILL CHURCH RD
 TAKE HWY 421, TURN LEFT ON OLD 421,
 TURN LEFT ON MCDOUGALD RD, TURN LEFT ON
 SPRING HILL CHURCH, LOT IS 2/10 MILE ON
 THE LEFT PRUSSELL
 PREMISE # 28592667
 LAND NOTES : LXMN 7/07/05 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 60X68 3BR SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/28/07 11/28/07	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001525807 If there are any questions or concerns I can be reached at 910-893-2252 or 910-814-2192. Port-a-john should be delivered thursday. Temp service pole should be in position. Thank you Elwood Sherman
A814 01	12/07/07 12/06/07	TI CA	ADDRESS CONFIRMATION VRU #: 001531771
B103 01	12/07/07 12/07/07	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001531805
E207 01	12/07/07 12/07/07	FS AP	R*ELEC TEMP SERVICE POLE VRU #: 001531813
A814 02	12/07/07 12/11/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001531789 √2850 SPRING HILL CHURCH RD
B105 01	12/11/07 12/11/07	FS AP	R*OPEN FLOOR VRU #: 001532902
B109 01	1/29/08 1/29/08	JH DA	R*BLDG ROUGH IN > 2500 VRU #: 001553916 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
E203 01	1/29/08 1/29/08	JH DA	R*ELEC ROUGH IN > 2500 VRU #: 001553924 1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw.

ADDRESS : 2850 SPRING HILL CHURCH RD SUBDIV:
 TENANT, NBR: 2 16873
 CONTRACTOR : PHONE :
 OWNER : SHERMAN ELWOOD & DANA #7 PHONE : (910) 893-2252
 PARCEL : 13-0519- - -0078- -06-
 APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
M403 01	1/29/08	JH	R*MECH ROUGH IN > 2500 VRU #: 001553932
	1/29/08	DA	1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
P303 01	1/29/08	JH	R*PLUMB ROUGH IN > 2500 VRU #: 001553940
	1/29/08	DA	1)Need 2 studs under lvl to left of garage door. 2)Missing nail guards in garage. 3)Ground all metal boxes with green ground screw. 4)Replace all insulation in garage used for fire stopping. 5)Missing nails in floor joist hangers @ bottom of stairs & beside stairs. 6)Rodent proof all holes under tubs & showers. 7)Need to support water lines @ spare bath tub per code. 8)Exhaust fans need to be pipped to the outside. 9)Add stud @ end of shower in master bath. 10)Leaks in drain line under house to left of crawl door see Mike.
B109 02	1/31/08	JH	R*BLDG ROUGH IN > 2500 VRU #: 001555036
	1/31/08	AP	
E203 02	1/31/08	JH	R*ELEC ROUGH IN > 2500 VRU #: 001555044
	1/31/08	AP	
M403 02	1/31/08	JH	R*MECH ROUGH IN > 2500 VRU #: 001555051
	1/31/08	AP	
P303 02	1/31/08	JH	R*PLUMB ROUGH IN > 2500 VRU #: 001555069
	1/31/08	AP	
I129 01	2/05/08	FS	R*INSULATION INSPECTION VRU #: 001557677
	2/05/08	AP	
H824 01	6/18/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001629203

PREPARED 10/09/08, 14:00:35

Harnett County

INSPECTION TICKET

INSPECTOR: IVR

PAGE 4

DATE 10/10/08

ADDRESS : 2850 SPRING HILL CHURCH RD

SUBDIV:

TENANT, NBR: 2

16873

CONTRACTOR :

PHONE :

OWNER : SHERMAN ELWOOD & DANA #7

PHONE : (910) 893-2252

PARCEL : 13-0519- - -0078- -06-

APPL NUMBER: 05-50012544 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 01	6/18/08 10/10/08 <i>10-10-8</i>	AP TI <i>AP</i>	FOUR TRADE FINAL VRU #: 001690148

COMMENTS AND NOTES

TS

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: IV

PERMIT NUMBERS

Owner: Elwosh Sherman

Building Permit No.: 5-5-12544

911 Address: 2858 Springle Hill Ct S

Electrical Permit No.: 5-5-12544

Insulation Permit No.: 5-5-12544

Plumbing Permit No.: 5-5-12544

Mech. Permit No.: 5-5-12544

MFG. Home: _____

State: _____ Zip Code: _____

Date: 10-10-8

Fred Spelling

Building Official