

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 05-500 12662

Applicant: *Sam*

Date Evaluated: 6-29

Property Size: 345

Property Recorded: 2005

Address:

Proposed Facility:

Design Flow (.1949): 360

Location of Site: *sa 1125*

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

Profile #	1940 Landscape Position/Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/Texture	1941 Consistence Mineralogy	1942 Soil Wetness/Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
1	<i>Less than 2%</i>	0-32	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		32-42	<i>SBK SIL</i>	<i>FR JR</i>					
2		0-28	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		28-42	<i>SBK SIL</i>	<i>FR JR</i>					
7		0-30	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		30-42	<i>SBK SIL</i>	<i>FR JR</i>					
4		0-30	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		30-42	<i>SBK SIL</i>	<i>FR JR</i>					
5		0-30	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		30-42	<i>SBK SIL</i>	<i>FR JR</i>					
6		0-30	<i>Gr SL</i>	<i>VFR JR</i>		<i>48</i>			<i>.5</i>
		30-42	<i>SBK SIL</i>	<i>FR JR</i>					

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	<i>Colt</i>	<i>W/P</i>
Site LTAR	<i>.5</i>	<i>.25</i>

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: *[Signature]*
 Others Present: *Phot by E.F.*

*1 x 240 18-24 290Lr
 Change to 25% Red. (S) to same size*

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).

