

Applicant:

Date Evaluated:

Address:

Address:

Property Size:

Proposed Facility:

Design Flow (.1949):

Property Recorded:

Location of Site:

Water Supply: ☐ Public ☐ Individual ☐ Well ☐ Spring ☐ Other

Evaluation Method: ☐ Auger Boring ☐ Pit ☐ Cut

Type of Wastewater: ☐ Sewage ☐ Industrial Process ☐ Mixed

Profile #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
1	L 2-3%	0-18	SL	FR ON 1st SP					.4
		18-42	SL	SODRY 1st SP	30				
2	L 2-3%	0-15							.35
		15-42			32				
3	L	6-18							.35
		18-42			34				
4	L	0-14							.35
		14-42			30				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	cor	cor
Site LTAR	.36	.36

Other Factors (.1946): _____

Site Classification (.1948):

Evaluated By:

Others Present:

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			SP-SLIGHTLY STICKY
CC-CONCLAVE SLOPE		CL-CLAY LOAM			P-PLASTIC
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			VP-VERY PLASTIC
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).

A large grid for site profile and feature mapping. The grid is approximately 30 units wide by 40 units high. It is used for plotting profile locations and other site features.

I, MICHAEL P. GRIFFIN, certify that under my direction and supervision this map was drawn from an actual field survey; that the error of closure of the survey as calculated by coordinates is 1: 10,000+; that the area shown hereon was calculated by coordinates.

Witness my hand and seal this day of MONTH 2005.

MAP #2005 PAG 425
HARNETT CO. REGISTRY

BETH E. OVERBY
D.B. 1778 PG. 657
PIN #0664-79-9191.000

WILLIAM & LINDA ANDREWS
D.B. 1841 PG. 532
PIN #0665-70-7320.000


SITE PLAN APPROVAL

DISTRICT RAZD

#BECKA00018

8-2-05

ZONING ADMINISTRATOR



SETBACKS
FRONT 35'
REAR 25'
SIDE 10'

LEGEND

EIP EXISTING IRON PIPE
IPS IRON PIPE SET
R/W RIGHT OF WAY
N/F NOW OR FORMERLY

