

HARNETT COUNTY HEALTH DEPARTMENT

HTE 05-50012748

IMPROVEMENT PERMIT

22098

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) A.L. CHAMPION New Installation Septic Tank
 Property Location: SR# 1006 OLD STAGE RD Repairs Nitrification Line

Subdivision WILLIAM B. RAY Lot # 3

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (360 sqd) Lot Size: .50 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 5 exact length of each ditch 60 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain Required: _____ Linear feet


Date: 2/26/05

Signed: [Signature] RS (OLIVER TOLKOFF)

Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- * MAINTAIN ALL SETBACKS
- * CALL WITH ANY QUESTIONS PRIOR TO INSTALLATIONS



HEALTH DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22098. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name A. L. CHAMPION Telephone # 919-625-4822

Address 88 COLBY LN ANGIER NC 27501

Property Location SR# 1006 Road Name OLD STAGE RD

Subdivision WILLIAM BRAY Lot # 3 # Bedrooms Proposed 3 (360 sq ft) Lot Size .50 ac

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines

[] Conventional Other 25% REDUCTION SYSTEM

[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal


NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 5 Length of lines 60 Ft.

Width of ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.


Signature of Authorized Agent for Harnett County

8/25/05
Date