

HTE#05-50012938

IMPROVEMENT PERMIT 22208

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) WELLONS REALTY New Installation Septic Tank Repair

Property Location: SR# 2027 HORSESHOE BEND RD Nitrification Line Expansion

Subdivision THE PINES Lot # 4

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed : 3 (360 gpd) Lot Size: .52AC

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other PUMP TO CONVENTIONAL

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 ft. exact length of each ditch 40 ft. width of ditches 3 ft. depth of ditches 12 in.


French Drain Required: _____ Linear feet

Date: 9/19/05
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKSDORF)
 Environmental Health Specialist

- * MAINTAIN ALL SETBACKS
- * USE 3 1/2" SCH 40 VALVES
- 2' PRESSURE HEAD
- 2" SCH 40 PIPE
- 23 gpm @ 9' TDH
- * MINIMUM OF 6" OF COVER NEEDED OVER DRAINFIELD



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22208. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

WELONS REALTY 892-3123
Name Telephone #
PO Box 130 DUNN NC 28334
Address
2027 HOBBESHOE BEND RD
Property Location SR# Road Name
THE PINES 4 3 (360 sqd) .52AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines
[] Conventional Other PUMP TO CONVENTIONAL
[] Basement [] With Plumbing [] Without Plumbing
Water Supply: [] Well Public Water Supply Minimum Well Setback: 50 Ft.
Septic Tank 1000 gal Pump Chamber 1000 gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 40 Ft.
Width of ditches 3 ft. Depth of ditches 12 inches
French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

7/19/05
Signature of Authorized Agent for Harnett County _____
Date 23