

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: _____ Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
		1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Glass	1944 Restr. Horiz	
1 L	0-18	SL	CL GN NSNP					3
	18-42	SL	SL Fm 1 3/4 SS.P	32	10yd 5.2			
2 L	0-18	SL	CL GN NSNP					3
	18-42	SL	SL Fm 1 3/4 SS.P	34	10yd 5.2			
3 L	0-15	SL	CL GN NSNP					3
	15-42	SL	SL Fm 1 3/4 SS.P	34	10yd 5.2			

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	25' b	25' 0" / UP
LTAR	.3	.3 / .15'

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: _____
 Others Present: _____