

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		OTHER PROFILE FACTORS				Profile Class & LTAR
		1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
1 L	0-18	SL	FL GW NSNP					.4
	18-42	SL	SLFM 1/2 SS.P	36" P.M.				
2 L	0-15	SL	FL GW NSNP					.4-35
	15-42	SL	SLFM 1/2 SS.P	36" P.M.				
3 L	0-16	SL	FL GW NSNP					.4
	16-42	SL	SLFM 1/2 SS.P	36" P.M.				
4 L	0-18	SL	FL GW NSNP					.4
	18-42	SL	SLFM 1/2 SS.P	36" P.M.				
5 L	0-12	SL	FL GW NSNP					.4-35
	12-36	SL	SLFM 1/2 SS.P	24" + GOOD FOR GW				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	25%10	25%10 - LPP
Site LTAR	.4.35	-35

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: _____
 Others Present: _____