

HTE # 05-50013339

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

18186

OPERATIONS PERMIT

Name: (owner) SHOWCASE CONSTRUCTION New Installation Septic Tank Repair

Property Location: SR# 1124 RAMBEAU RD Nitrification Line Expansion

Subdivision WESTERFIELD Fm Lot # 38 Tax ID # _____ Quadrant # _____

Contractor: OTIS STRICKLAND Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other POLYSTYRENE AGG. TRENCH

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field	No. of ditches <u>1</u>	exact length of each ditch <u>300</u> ft.	width of ditches <u>3</u> ft.	depth of ditches <u>12</u> in.
------------------------------	----------------------------	--	----------------------------------	-----------------------------------

French Drain Required: _____ Linear feet

Date: 2/2/06

PERMIT NO. 20244

Inspected by: [Signature]

* REPAIR LOCATED ON SEPTIC EASEMENT BEHIND PROPERTIES ACROSS THE STREET (PUMP CONV. REPAIR) SEE IMPROVEMENT PERMIT

