

HTE# 05-5-13400 R
13401R
13402R

IMPROVEMENT PERMIT 22600

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) John W. Tatum New Installation Septic Tank Repair
 Property Location: SR# 1407 Wade Stephenson Rd Nitrification Line Expansion
 Subdivision Fieldstone Farms Lot # 11
 Tax ID# _____ Quadrant # _____
 Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: 6.18 ac

Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property.
 Subject to final approval.

Type of system: Conventional Other 25% Reduction System

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
 Drainage Field ditches 3 of each ditch 100 ft. ditches 3 ft. ditches 18-22 in.

French Drain Required: _____ Linear feet


Date: 11/7/2006

PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: Bryan McSwain R.S.
 Environmental Health Specialist

- * Maintain all setbacks
- * Run ditches on contour
 + NO DEEPER than 22 inches
- * System has been flagged



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22600. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. ***This authorization will be invalid if ownership, site plans, or intended use change.***

John W. Tatum Name 919 427-5892 Telephone #

504 Schnapps Lane Holly Springs, N.C. 27540 Address

1407 Property Location SR# Wade Stephens Road Name

Fieldstone Farm Subdivision 11 Lot # 3 (360 gal) # Bedrooms Proposed 6.18 Ac Lot Size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other 25% Reduction System

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 100 Ft.

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

Debra McSwain, R.S.
Signature of Authorized Agent for Harnett County

11/7/2006
Date