

HTE# 05-500136524

IMPROVEMENT PERMIT 22489

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) CAVINESS LAND DEVELOPMENT New Installation Septic Tank Repair

Property Location: SR# 1120 OVERHILLS RD Nitrification Line Expansion

Subdivision STONECROSS Lot # 34

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed : 3 (360 sq ft) Lot Size: .35 AC

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 ft. exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 24-32 in.


French Drain Required: _____ Linear feet

Date: 1/25/06
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKSCOFF)
Environmental Health Specialist

- * MAINTAIN ALL SEPTIC LINES
- * SYSTEM MAY BE CHANGED TO 3 50' LINES
- * CALL W/ ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22489. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

CAVINESS LAND DEVELOPMENT 481-0503
Name Telephone #
2816 RAEFORD RD STE 200 FAYETTEVILLE NC 28303
Address
1120 OVERHILLS RD
Property Location SR# Road Name
STONECROSS 34 3(360sqft) .35 AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines

Conventional [] Other _____

[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal


NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 2 Length of lines 75 Ft.

Width of ditches 3 ft. Depth of ditches 24-32 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

 RS
Signature of Authorized Agent for Harnett County

1/25/06
Date