

H7

5-53013677

OPERATIONS PERMIT

Name: (owner) Hamilton Builders [X] New Installation [X] Septic Tank [] Repair

Property Location: SR# 1229 [X] Nitrification Line [] Expansion

Subdivision AVA Ridge Lot # 3 Tax ID # Quadrant #

Contractor: Ron Wall Registration #

Basement with Plumbing: [] Garage: [X] Lines ok Tank ok

Water Supply: [] Well [X] Public [] Community Waiting on Tire chip sheet & Distance From Well: 50 ft. Tire chip clean-up

Following are the specifications for the sewage disposal system on above captioned property.


Type of system: [] Conventional [X] Other Tire chip

Size of tank: Septic Tank: 1000 gallons Pump Tank: gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 300 ft. width of ditches 3 ft. depth of ditches 18.24 in.

French Drain Required: Linear feet Date: 3-9-06

PERMIT NO. 22423 Inspected by: Jo Lora



Central Carolina Holdings, LLC
1616 McKoy Town Road
Cameron, NC 28326

These tire chips meet the Approval of Tire Chip Aggregate for On-Site Wastewater Systems, **Approval No. TCA-03**, approval by NCDENR Division of Environmental Health, On-Site Wastewater Section.

Sold To: Wall Excavation

Date: 2-23-06