

HTE# 05-50013681

IMPROVEMENT PERMIT 22475

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) OAK CITY HOMES New Installation Septic Tank Repair
Property Location: SR# 1437 BALLARO RD Nitrification Line Expansion
Subdivision BALLARO WOODS Lot # 58
Tax ID# _____ Quadrant # _____
Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: .58 AC

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property.
Subject to final approval.

Type of system: Conventional Other PUMP TO 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 ft. exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 12 in. ^{MAX!}


French Drain Required: _____ Linear feet

Date: 1/13/06
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

- * MAINTAIN ALL SETBACKS
- * PUMP = 23 gpm @ 7' TDH
- * MANHOLE
3 1/2" SCH 40 VALVES
2" PRESSURE HEAD
2" SCH 40 PIPE
- * MINIMUM OF 6" OF COVER NEEDED OVER DRAINFIELD

Signed: [Signature] OLIVER TOLKSDORF
Environmental Health Specialist



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22475. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Oak City Homes 919-833-5526
Name Telephone #

PO Box 6127 RALEIGH NC 27628
Address

1437 BALLARD RD
Property Location SR# Road Name

BALLARD WOODS 58 3 (360 gal) .58 AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

- New Installation [] Repair Septic Tank Nitrification Lines
[] Conventional Other PUMP TO 25% REDUCTION SYSTEM
[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber 1000 gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 100 Ft.

Width of ditches 3 ft. Depth of ditches 12 inches MAX!

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] RS
Signature of Authorized Agent for Harnett County

1/13/06
Date