

HTE # 05-5-1367

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

18149

OPERATIONS PERMIT

Name: (owner) Comfort Homes New Installation Septic Tank Repair

Property Location: SR# 1412 Nitrification Line Expansion

Subdivision Forest Trail Lot # 58 Tax ID # _____ Quadrant # _____

Contractor: Jeff Thompson Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 500 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: _____ Linear feet

Date: 4/25/2006

PERMIT NO. 22554

Inspected by: Bryan McFusion, P.E.

