

ADDRESS : 150 GLEN VIEW CT
CONTRACTOR : Y & M PROPERTIES INC
OWNER : POPE MARY T. #12
PARCEL : 07-0680- - -0132- -12-
APPL NUMBER: 06-50013807 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO HWY 27 TURN LEFT AT BUIES CREEK
TURN LEFT ON BILL AVERY RD LEFT ON GLEN
VIEW CT LOT 12 JB

SUBDIV:
PHONE : (919) 639-2934
PHONE :

STRUCTURE: 000 000 50 X 60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/07/07 <u>3-7</u>	TI <u>AI</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001366889 WOULD LIKE IN THE AM ***** ***** *****

COMMENTS AND NOTES

ADDRESS . : 150 GLEN VIEW CT SUBDIV:
CONTRACTOR : Y & M PROPERTIES INC PHONE : (919) 639-2934
OWNER . . : POPE MARY T. #12 PHONE :
PARCEL . . : 07-0680- - -0132- -12-
APPL NUMBER: 06-50013807 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO HWY 27 TURN LEFT AT BUIES CREEK
TURN LEFT ON BILL AVERY RD LEFT ON GLEN
VIEW CT LOT 12 JB

STRUCTURE: 000 000 50 X 60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSE 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/07/07 3/07/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001366889 WOULD LIKE IN THE AM ***** ***** *****
A814 01	3/13/07	TI	ADDRESS CONFIRMATION VRU #: 001369875
B103 01	<u>3-13</u> 3/13/07	<u>TI</u> TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001369883

----- COMMENTS AND NOTES -----

ADDRESS . . : 150 GLEN VIEW CT SUBDIV:
CONTRACTOR : Y & M PROPERTIES INC PHONE : (919) 639-2934
OWNER . . . : POPE MARY T. #12 PHONE :
PARCEL . . . : 07-0680- - -0132- -12-
APPL NUMBER: 06-50013807 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO HWY 27 TURN LEFT AT BUIES CREEK
TURN LEFT ON BILL AVERY RD LEFT ON GLEN
VIEW CT LOT 12 JB

STRUCTURE: 000 000 50 X 60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/07/07 3/07/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001366889 WOULD LIKE IN THE AM ***** ***** *****
B103 01	3/13/07 3/13/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001369883
A814 01	3/13/07 3/13/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001369875 150 Glen View Ct Lot 12
B105 01	3/14/07 3/15/07	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001371004
R425 01	4/05/07	TI	FOUR TRADE ROUGH IN VRU #: 001384726

DA KS

COMMENTS AND NOTES

ADDRESS : 150 GLEN VIEW CT
CONTRACTOR : Y & M PROPERTIES INC
OWNER : POPE MARY T. #12
PARCEL : 07-0680- - -0132- -12-
APPL NUMBER: 06-50013807 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO HWY 27 TURN LEFT AT BUIES CREEK
TURN LEFT ON BILL AVERY RD LEFT ON GLEN
VIEW CT LOT 12 JB

SUBDIV:
PHONE : (919) 639-2934
PHONE :

STRUCTURE: 000 000 50 X 60 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/07/07 3/07/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001366889 WOULD LIKE IN THE AM ***** ***** *****
B103 01	3/13/07 3/13/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001369883
A814 01	3/13/07 3/13/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001369875 150 Glen View Ct Lot 12
B105 01	3/14/07 3/15/07	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001371004
R425 01	4/05/07 4/05/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001384726 1. Cannot bundle wire beneath panel 2. Fire block above fireplace. 3. Need hurricane hangars on girdir truss for 1386 pounds and 2300 pounds. 4. Support gable end plywood sheathing 2 foot on center and on seams nailed per code. 5. nail blocking for osb seams OKto insulate
I129 01	4/10/07 4-10	TI AP	R*INSULATION INSPECTION VRU #: 001385384
R425 02	4/10/07 4-10	TI AP	FOUR TRADE ROUGH IN VRU #: 001385376

KS

COMMENTS AND NOTES

ADDRESS : 150 GLEN VIEW CT
CONTRACTOR : Y & M PROPERTIES INC
OWNER : POPE MARY T. #12
PARCEL : 07-0680- - -0132- -12-
APPL NUMBER: 06-50013807 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 TO HWY 27 TURN LEFT AT BUIES CREEK
TURN LEFT ON BILL AVERY RD LEFT ON GLEN
VIEW CT LOT 12 JB

SUBDIV:
PHONE : (919) 639-2934
PHONE :

STRUCTURE: 000 000 50 X 60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/07/07 3/07/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001366889 WOULD LIKE IN THE AM ***** ***** *****
B103 01	3/13/07 3/13/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001369883
A814 01	3/13/07 3/13/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001369875 150 Glen View Ct Lot 12
B105 01	3/14/07 3/15/07	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001371004
R425 01	4/05/07 4/05/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001384726 1. Cannot bundle wire beneath panel 2. Fire block above fireplace. 3. Need hurricane hangars on girdir truss for 1386 pounds and 2300 pounds. 4. Support gable end plywood sheathing 2 foot on center and on seams nailed per code. 5. nail blocking for osb seams OKto insulate
I129 01	4/10/07 4/10/07	KS AP	R*INSULATION INSPECTION VRU #: 001385384
R425 02	4/10/07 4/10/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001385376
H824 01	5/03/07 5/03/07	JM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001406560
R429 01	5/10/07 5/09/07	TI CA	FOUR TRADE FINAL VRU #: 001407022
R429 02	5/14/07 5/14/07	TI CA	FOUR TRADE FINAL VRU #: 001407246 CANCELLED PER CONTRACTOR. -AD
R429 03	5/15/07 5/15/07	TI CA	FOUR TRADE FINAL VRU #: 001409721 WANTS THIS INSPECTION IN THE AFTERNOON.
R429 04	5/16/07	TI	FOUR TRADE FINAL VRU #: 001410091

5-16

AP

KS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential
Type of Construction: V
Owner of Building: Y+M Properties
Building Address: 150 Glen View Ct
Zoning District: _____
Zoning Permit No.: _____
Date: 5-16-07
K. Slath

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: _____

06-50013807

Building Official

Zoning Official