

HTE# 06-50013826

IMPROVEMENT PERMIT 22487

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MIKE RAY New Installation Septic Tank Repair
Property Location: SR# 1291 Old USA 21 Nitrification Line Expansion
Subdivision MAMIE BELL RIDGE Lot # 38
Tax ID# _____ Quadrant # _____
Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: .77

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 1 ft. of each ditch 180 ft. ditches 3 ft. ditches 24 in.


French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 1/24/06
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

Signed: [Signature] RS (OLIVER TOLKSOFF)
Environmental Health Specialist

*MAINTAIN ALL SETBACKS
*START DRAINLINE SO THAT THE LAST RUN WILL BE 50' LONG



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22487. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

MIKE RAY 919-499-5882
Name Telephone #

3417 SPRING HILL CH. RD. LILLINGTON NC 27546
Address

1291 OL0 05421
Property Location SR# Road Name

MAMIE BELL RIDGE 38 3(360sqft) .77
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other 25% REDUCTION SYSTEM

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 1 Length of lines 180 Ft.

Width of ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

RS
Signature of Authorized Agent for Harnett County

1/24/06
Date