

HTE# 06-50013861R

IMPROVEMENT PERMIT 22803

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) STRONG BUILT HOMES New Installation Septic Tank Repair

Property Location: SR# 1415 RAWLS CHURCH RD Nitrification Line Expansion

Subdivision WYNDHAM PLACE Lot # 32

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: .63 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 20 in.

French Drain Required: _____ Linear feet


Date: 2/20/06

PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKADOFF)
Environmental Health Specialist

- * MAINTAIN ALL SETBACKS
- * IRRIGATION LINE IN LANDSCAPED AREA MUST BE RELOCATED TO RUN DOWN PROPERTY LINE ON RAWLS CHURCH RD.
- * CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22803. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

STRONG BUILT HOMES 919-662-2624
Name Telephone #

732 TREBOR DR GARNER NC 27529
Address

RAWLS CHURCH RD ↔ 1415
Property Location SR# Road Name

WINDHAM PLACE 32 3 (360 gpd) .63 ac
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM


- New Installation Repair Septic Tank Nitrification Lines
 Conventional Other 25% REDUCTION SYSTEM
 Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 100 Ft.
Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 100 Ft.
Width of ditches 3 ft. Depth of ditches 20 inches
French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.


Signature of Authorized Agent for Harnett County

2/20/06
Date