

HARNETT COUNTY HEALTH DEPARTMENT

HTE# 06-50013874

IMPROVEMENT PERMIT 22503

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Kenneth Cumming New Installation [X] Septic Tank [X] Repair []

Property Location: SR# 1125 Nitrification Line [X] Expansion []

Subdivision Forest Oaks Lot # 75

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (44x41) 360 sq ft Lot Size: .80

Basement with Plumbing: [] Garage: [X]

Water Supply: [] Well [X] Public [] Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [] Conventional [X] Other Pump to 25% Reduction SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 225 ft. width of ditches 3 ft. depth of ditches 18.24 in.

French Drain Required: _____ Linear feet

Date: 01-25-06

PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: J. W. [Signature] Environmental Health Specialist

