HAI TT COUNTY HEALTH DEPART NT 18315

HTE # 06-500 13922R ENVIRONMENTAL HEALTH SECTION

OPERATIONS PERMIT

Name: (owner) Bill Clark Homes ☒ New Installation ☒ Septic Tank ☐ Repair

Property Location: SR# 1139 ☒ Nitrification Line ☐ Expansion

Subdivision Pattons Point Lot # 110 Tax ID # _____ Quadrant # _____

Contractor: Jones Backhoe Registration # _____

Basement with Plumbing: ☐ Garage: ☒

Line OK Tank ok
Need Tire chips clean-up

Water Supply: ☐ Well ☒ Public ☐ Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☐ Conventional ☒ Other Tire Chips

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field	No. of ditches 2	exact length of each ditch 100 ft.	width of ditches 3 ft.	depth of ditches 18-24 in.

French Drain Required: _____ Linear feet Date: 6.29.06

PERMIT NO. 22521 Inspected by: [illegible]


51
21
121
21
21
21
52
21
21
21