

HTE# 06-50014140

# IMPROVEMENT PERMIT 22825

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) RBC HOMES INC New Installation  Septic Tank  Repair   
Property Location: SR# 1125 LEMUEL BLACK RD Nitrification Line  Expansion   
Subdivision CARLIE HILLS FARMS Lot # 37  
Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Number of Bedrooms Proposed: 4 (480 sqd) Lot Size: .70 AC

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 100 ft.

**Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.**

Type of system:  Conventional  Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface No. of exact length width of depth of  
Drainage Field ditches 1 of each ditch 270 ft. ditches 3 ft. ditches 18-24 in.


French Drain Required: \_\_\_\_\_ Linear feet

**This permit is subject to revocation if site plans or intended use change.**

Date: 3/15/06  
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

Signed:  AS (OLIVER TOLKSDORF)  
161' Environmental Health Specialist

\* MAINTAIN ALL SETBACKS  
\* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22825. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

RBC HOMES INC 423-3555  
Name Telephone #

PO Box 755 FAYETTEVILLE NC 28302  
Address

1125 LEMUEL BLACK RD  
Property Location SR# Road Name

CARLIE HILLS FARMS 37 4(480gpd) .70 AC  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation  Repair  Septic Tank  Nitrification Lines

Conventional  Other 25% REDUCTION SYSTEM

Basement  With Plumbing  Without Plumbing

Water Supply:  Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal


**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 1 Length of lines 270 Ft.

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

 RS  
Signature of Authorized Agent for Harnett County

3/15/06  
Date