

HTE# 06-5-14214

IMPROVEMENT PERMIT 22822

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) J+S DEVELOPMENT New Installation Septic Tank Repair
Property Location: SR# 1125 LEMUEL BLACK RD Nitrification Line Expansion
Subdivision CARLIE HILLS FARMS Lot # 43
Tax ID# _____ Quadrant # _____
Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: .76 ac

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 3 ft. of each ditch 160 ft. ditches 3 ft. ditches 24 in.


French Drain Required: _____ Linear feet

Date: 3/15/06
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature] RS (OLIVER TOLKSOOF)
Environmental Health Specialist

*MAINTAIN ALL SETBACKS
*CALL WITH ANY QUESTIONS
PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 2222. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. ***This authorization will be invalid if ownership, site plans, or intended use change.***

J+S DEVELOPMENT Name 937-0692 Telephone #

1172 VICKERY RD SANFORD NC 27352 Address

1125 Property Location SR# LEMOBEL BLACK RD Road Name

CARLIG HILLS FARMS 43 Subdivision 3 (360 gpd) Lot # # Bedrooms Proposed .76 AC Lot Size

TYPE OF SYSTEM

New Installation [] Repair Septic Tank Nitrification Lines

[] Conventional Other 25% REDUCTION SYSTEM

[] Basement [] With Plumbing [] Without Plumbing

Water Supply: [] Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 3 Length of lines 100 Ft.

Width of ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] Signature of Authorized Agent for Harnett County

3/15/06 Date