

HTE# 06-5-14220

IMPROVEMENT PERMIT 22570

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Juan Alberto Hernandez Herrero New Installation Septic Tank Repair

Property Location: SR# 1448 Atkins Rd. Nitrification Line Expansion

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 5 (600 yod) Lot Size: 1.76 Ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 m - ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1250 gallons Pump Tank: _____ gallons


Subsurface No. of exact length width of depth of
Drainage Field ditches 6 of each ditch 112 ft. ditches 3 ft. ditches 18-24 in.

French Drain Required: _____ Linear feet

conv. REP Date: 4/18/2006
45' x 112' PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

* Maintain all setbacks
* Ditches may not be on contour, but must not be installed deeper than 24 inches



SR 1448

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22570. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance.

This authorization will be invalid if ownership, site plans, or intended use change.

Name Juan Alberto Hernandez Herrera Telephone # 919-796-7457

Address 1291 Lafayette Rd Fuquay Varina, N.C. 27526

Property Location SR# 1448 Road Name Atkins

Subdivision _____ Lot # _____ # Bedrooms Proposed 5 (600 sq ft) Lot Size 1.76 Ac

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other _____

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1250 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 6 Length of lines 112 Ft.

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

B. Sue McSwain, R.S.
Signature of Authorized Agent for Harnett County

4/18/2006
Date