

Initial Application Date: 3/8/06

ENV. Rec'd
3/14/06

Application # DU-50014240
1156037

COUNTY OF HARNETT LAND USE APPLICATION
Central Permitting 102 E. Front Street, Lillington, NC 27648 Phone: (910) 893-4759 Fax: (910) 893-2793

LANDOWNER: Millennium Homes Mailing Address: Po Box 727
City: Dunn State: NC Zip: 28335 Phone #: 910 892-4345
APPLICANT: Danny Norris Mailing Address: Po Box 727
City: Dunn State: NC Zip: 28335 Phone #: 910 892-4345

PROPERTY LOCATION: SR #: 1201 SR Name: Penderosa Rd.
Address: Quail Hollow
Parcel: 099567800 0006 23 PIN: 9501-30-1739.000
Zoning: RA20R Subdivision: Carolina Seasons Lot #: 4c Lot Size: .45 AC
Flood Plain: X Panel: 75 Watershed: N/A Dead Book/Page: 2191 778-780 Plat Book/Page: E/B56
DIRECTIONS TO THE PROPERTY FROM LILLINGTON: 27 W / (TR) on Johnsonville School Rd. / (TR) on Penderosa Rd. / (TR) on Penderosa Trail

PROPOSED USE:
 SFD (Size 58 x 34) # Bedrooms 3 # Baths 2 1/2 Basement (w/wo bath) 1 Garage 24x26 Deck 14x12 Crawl Space Slab
 Multi-Family Dwelling No. Units _____ No. Bedrooms/Unit _____
 Manufactured Home (Size _____ x _____) # of Bedrooms _____ Garage _____ Deck _____
 Number of persons per household Spec.
 Business Sq. Ft. Retail Space _____ Type _____
 Industry Sq. Ft. _____ Type _____
 Church Seating Capacity _____ Kitchen _____
 Home Occupation (Size _____ x _____) # Rooms _____ Use _____
Additional Information:
 Accessory Building (Size _____ x _____) Use _____
 Addition to Existing Building (Size _____ x _____) Use _____
 Other _____

Water Supply: County Well (No. dwellings _____) Other Environmental Health Site Visit Date: _____

Sewage Supply: New Septic Tank Existing Septic Tank County Sewer Other

Erosion & Sedimentation Control Plan Required? YES NO

Property owner of this tract of land own land that contains a manufactured home w/in five hundred feet (500') of tract listed above? YES NO

Structures on this tract of land: Single family dwellings Manufactured homes _____ Other (specify) _____

Required Residential Property Line Setbacks: proposed

	Minimum	Actual
Front	<u>35</u>	<u>50</u>
Rear	<u>25</u>	<u>65</u>
Side	<u>10</u>	<u>18</u>
Corner	<u>20</u>	<u>5</u>
Nearest Building	<u>10</u>	<u> </u>

If permits are granted I agree to conform to all ordinances and the laws of the State of North Carolina regulating such work and the specifications or plans submitted. I hereby swear that the foregoing statements are accurate and correct to the best of my knowledge.

Danny Norris Signature of Owner or Owner's Agent
3/8/06 Date

This application expires 6 months from the initial date if no permits have been issued

A RECORDED SURVEY PLAT AND RECORDED DEED ARE REQUIRED WHEN APPLYING FOR A LAND USE APPLICATION

3/135

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




"suit Copy"

SITE PLAN APPROVAL

DISTRICT BAZOR USE SFD

BED ROOMS 3

3/10/00 A. Duggins
Zoning Admin.



Quail Hollow

Millennial Homes

Lot 46 Ardina Seasons

"The Lexington"

SCALE: 1/4" = 10'

1" = 40'

HTE# 05-50012687

IMPROVEMENT PERMIT 22715

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Lyon Builders New Installation Septic Tank Repair
Property Location: SR# 1201 (Quail Hollow) Nitrification Line Expansion
Subdivision CAROLINA SEASONS Lot # C-4
Tax ID# _____ Quadrant # _____
Number of Bedrooms Proposed: 3 (55x70) 360 gpd Lot Size: .45 AC

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property.
Subject to final approval.

Type of system: Conventional Other Pump to 25% Reduction SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons


Subsurface Drainage Field No. of ditches 5 exact length of each ditch 40 ft. width of ditches 3 ft. depth of ditches 18-24 in. ^{max}
of 25% Reduction System

French Drain Required: _____ Linear feet

Date: 8-3-05
PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

This permit is subject to revocation if site plans or intended use change.

Signed: [Signature]
Environmental Health Specialist



Meet onsite
For Final Layout
MAY TRY TO INSTALL
AS 1x200 OR 2x100

MAINTAIN ALL
Set Back

Must meet onsite at least
2 days Before installing