
ADDRESS . . : 24 CACO DR
CONTRACTOR : SIGNATURE HOME BUILDERS
OWNER . . . : WMJ DEVELOPERS LLC
PARCEL . . . : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

SUBDIV: PLTN VINEYARD GREEN
PHONE : (910) 892-9299
PHONE :

DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
LEFT ON SCUPPONONG LEFT ON CACO LOT 54
JB

LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10 <u>3-23-10</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287

----- COMMENTS AND NOTES -----

ADDRESS : 24 CACO DR
CONTRACTOR : SIGNATURE HOME BUILDERS
OWNER : WMJ DEVELOPERS LLC
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)
SUBDIV: PLTN VINEYARD GREEN
PHONE : (910) 892-9299
PHONE :

DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
LEFT ON SCUPPONONG LEFT ON CACO LOT 54
JB

LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
			T/S: 03/29/2010 01:36 PM DJOHNSON
B103 01	3/30/10	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	<u>3:30-10</u>	<u>APB</u>	T/S: 03/29/2010 01:36 PM DJOHNSON

COMMENTS AND NOTES

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
OWNER : WMJ DEVELOPERS LLC PHONE :
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
LEFT ON SCUPPONONG LEFT ON CACO LOT 54
JB
LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON 24 caco dr lot 54 lillington 27546 T/S: 03/30/2010 04:05 PM TWARD
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON T/S: March 30, 2010 10:49 AM BSUTTON
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN CUSTOMER REQUEST PM INSPECTION T/S: 04/01/2010 08:13 AM VBROWN CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	<u>4-5-10</u>	<u>AEB</u>	T/S: 04/01/2010 08:14 AM VBROWN

COMMENTS AND NOTES

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
 OWNER : WMJ DEVELOPERS LLC PHONE :
 PARCEL : 11-0651- - -0057- -88-
 APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
 LEFT ON SCUPPONONG LEFT ON CACO LOT 54
 JB
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			24 caco dr lot 54 lillington 27546 T/S: 03/30/2010 04:05 PM TWARD
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			T/S: March 30, 2010 10:49 AM BSUTTON
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN
			CUSTOMER REQUEST PM INSPECTION T/S: 04/01/2010 08:13 AM VBROWN CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	4/05/10	AE	T/S: 04/01/2010 08:14 AM VBROWN
			missing nuts/washers (2) on right front corner of house. Also must have anchors within 1 foot of all joints in mudsill. Will check at rough in
R425 01	4/19/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001912088
	<u>4-19-10</u>	<u>DABS</u>	T/S: 04/16/2010 12:28 PM VBROWN

COMMENTS AND NOTES

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
 OWNER : WMJ DEVELOPERS LLC PHONE :
 PARCEL : 11-0651- - -0057- -88-
 APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
 LEFT ON SCUPPONONG LEFT ON CACO LOT 54
 JB
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON -----
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON ----- 24 caco dr lot 54 ----- lillington 27546 ----- T/S: 03/30/2010 04:05 PM TWARD -----
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON ----- T/S: March 30, 2010 10:49 AM BSUTTON -----
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN ----- CUSTOMER REQUEST PM INSPECTION T/S: 04/01/2010 08:13 AM VBROWN ----- CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	4/05/10	AE	T/S: 04/01/2010 08:14 AM VBROWN ----- missing nuts/washers (2) on right front corner of house. Also must have anchors within 1 foot of all joints in mudsill. Will check at rough in
R425 01	4/19/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001912088
	4/19/10	DA	T/S: 04/16/2010 12:28 PM VBROWN ----- 1. Need a structural nail plate at top plate of master bath lav vent. 2. Need installation instructions for fireplace/vent system. 3. Window at rear door must be tempered glass. 4. Bolt all porch bands to house. 5. Need 2 more hurricane ties on girder truss over rear bedroom. 6. Repair floor joist under house cut for plumbing. Ok to side/insulate
I129 01	4/22/10	TI	R*INSULATION INSPECTION VRU #: 001913672
R425 02	4/22/10	TI	FOUR TRADE ROUGH IN VRU #: 001913664

----- COMMENTS AND NOTES -----

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
OWNER : WMJ DEVELOPERS LLC PHONE :
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
LEFT ON SCUPPONONG LEFT ON CACO LOT 54
JB

LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON 24 caco dr lot 54 lillington 27546 T/S: 03/30/2010 04:05 PM TWARD
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON T/S: March 30, 2010 10:49 AM BSUTTON
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN CUSTOMER REQUEST PM INSPECTION T/S: 04/01/2010 08:13 AM VBROWN CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	4/05/10	AE	T/S: 04/01/2010 08:14 AM VBROWN missing nuts/washers (2) on right front corner of house. Also must have anchors within 1 foot of all joints in mudsill. Will check at rough in
R425 01	4/19/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001912088
	4/19/10	DA	T/S: 04/16/2010 12:28 PM VBROWN 1. Need a structural nail plate at top plate of master bath lav vent. 2. Need installation instructions for fireplace/vent system. 3. Window at rear door must be tempered glass. 4. Bolt all porch bands to house. 5. Need 2 more hurricane ties on girder truss over rear bedroom. 6. Repair floor joist under house cut for plumbing. Ok to side/insulate
I129 01	4/22/10	KS	R*INSULATION INSPECTION VRU #: 001913672
	4/22/10	AP	
R425 02	4/22/10	KS	FOUR TRADE ROUGH IN VRU #: 001913664
	4/22/10	DA	Operations instructions only at site. Need installation instructions T/S: 04/22/2010 04:01 PM KSLATTUM

PREPARED 4/23/10, 14:22:58
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 4/26/10

ADDRESS : 24 CACO DR
CONTRACTOR : SIGNATURE HOME BUILDERS
OWNER : WMJ DEVELOPERS LLC
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

SUBDIV: PLTN VINEYARD GREEN
PHONE : (910) 892-9299
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 03	4/26/10 <u>4-26</u>	TI <u>AP</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001915644 T/S: 04/23/2010 02:21 PM NTART

COMMENTS AND NOTES

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
 OWNER : WMJ DEVELOPERS LLC PHONE :
 PARCEL : 11-0651- - -0057- -88-
 APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
 LEFT ON SCUPPONONG LEFT ON CACO LOT 54
 JB

LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			√24 caco dr lot 54
			lillington 27546
			T/S: 03/30/2010 04:05 PM TWARD
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			T/S: March 30, 2010 10:49 AM BSUTTON
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN
			CUSTOMER REQUEST PM INSPECTION
			T/S: 04/01/2010 08:13 AM VBROWN
			CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	4/05/10	AE	T/S: 04/01/2010 08:14 AM VBROWN
			missing nuts/washers (2) on right front corner of house.
			Also must have anchors within 1 foot of all joints in mudsill. Will check at rough in
R425 01	4/19/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001912088
	4/19/10	DA	T/S: 04/16/2010 12:28 PM VBROWN
			1. Need a structural nail plate at top plate of master bath lav vent. 2. Need installation instructions for fireplace/vent system. 3. Window at rear door must be tempered glass. 4. Bolt all porch bands to house. 5. Need 2 more hurricane ties on girder truss over rear bedroom. 6. Repair floor joist under house cut for plumbing. Ok to side/insulate
I129 01	4/22/10	KS	R*INSULATION INSPECTION VRU #: 001913672
	4/22/10	AP	
R425 02	4/22/10	KS	FOUR TRADE ROUGH IN VRU #: 001913664
	4/22/10	DA	Operations instructions only at site. Need installation instructions
			T/S: 04/22/2010 04:01 PM KSLATTUM

ADDRESS : 24 CACO DR
CONTRACTOR : SIGNATURE HOME BUILDERS
OWNER : WMJ DEVELOPERS LLC
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

SUBDIV: PLTN VINEYARD GREEN
PHONE : (910) 892-9299
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 03	4/26/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001915644
	4/26/10	AP	T/S: 04/23/2010 02:21 PM NTART
H824 01	5/21/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001931617
	5/21/10	AP	T/S: 05/24/2010 09:20 AM SSTEWARD
			T/S: 05/24/2010 09:20 AM SSTEWARD
R429 01	6/15/10	VC	FOUR TRADE FINAL VRU #: 001940899
	6/15/10	CA	T/S: 06/15/2010 08:01 AM VBROWN
			KEVIN DAUGHTRY CALLED AND CAN 4 TRADE FIN.
R429 02	6/16/10	TT	FOUR TRADE FINAL TIME: 17:00 VRU #: 001941087
	<u>6-17</u>	<u>DA</u>	T/S: 06/15/2010 08:02 AM VBROWN
			CUSTOMER REQUEST PM INSP.

COMMENTS AND NOTES

- Tempered glass
- Receptacle at pennis ula

VIOLATION NOTICE

DO NOT REMOVE!

Harnett County Inspection Department

108 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: Signature Date: 6-17-10

Address: _____

Lot No.: _____ Permit No.: 06-5-14287

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|---|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water
Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: ① Need Receptacle at peninsula
② Tempered glass

Code Enforcement Official

Signature: KSO att Date: 6-17-10

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation

ADDRESS : 24 CACO DR SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : SIGNATURE HOME BUILDERS PHONE : (910) 892-9299
 OWNER : WMJ DEVELOPERS LLC PHONE :
 PARCEL : 11-0651- - -0057- -88-
 APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 201 TOWARD ANGIER TURN LEFT ON TRIPP RD
 LEFT ON SCUPPONONG LEFT ON CACO LOT 54
 JB
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 07 PARCEL

STRUCTURE: 000 000 61X47.3 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/23/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001898287
	3/23/10	AP	T/S: March 23, 2010 08:54 AM BSUTTON
A814 01	3/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902014
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			√24 caco dr lot 54
			lillington 27546
			T/S: 03/30/2010 04:05 PM TWARD
B103 01	3/30/10	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001902006
	3/30/10	AP	T/S: 03/29/2010 01:36 PM DJOHNSON
			T/S: March 30, 2010 10:49 AM BSUTTON
B105 01	4/01/10	VC	R*OPEN FLOOR TIME: 17:00 VRU #: 001903327
	4/01/10	CA	T/S: 03/31/2010 12:44 PM VBROWN
			CUSTOMER REQUEST PM INSPECTION
			T/S: 04/01/2010 08:13 AM VBROWN
			CUSTOMER CALLED AND CAN INSP ROLL OVER FOR MONDAY 4-5-10.
B105 02	4/05/10	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001903541
	4/05/10	AE	T/S: 04/01/2010 08:14 AM VBROWN
			missing nuts/washers (2) on right front corner of house.
			Also must have anchors within 1 foot of all joints in
			mudsill. Will check at rough in
R425 01	4/19/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001912088
	4/19/10	DA	T/S: 04/16/2010 12:28 PM VBROWN
			1. Need a structural nail plate at top plate of master bath
			lav vent. 2. Need installation instructions for
			fireplace/vent system. 3. Window at rear door must be
			tempered glass. 4. Bolt all porch bands to house. 5. Need 2
			more hurricane ties on girder truss over rear bedroom. 6.
			Repair floor joist under house cut for plumbing. Ok to
			side/insulate
I129 01	4/22/10	KS	R*INSULATION INSPECTION VRU #: 001913672
	4/22/10	AP	
R425 02	4/22/10	KS	FOUR TRADE ROUGH IN VRU #: 001913664
	4/22/10	DA	Operations instructions only at site. Need installation
			instructions
			T/S: 04/22/2010 04:01 PM KSLATTUM
R425 03	4/26/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001915644

04781084

ADDRESS : 24 CACO DR
CONTRACTOR : SIGNATURE HOME BUILDERS
OWNER : WMJ DEVELOPERS LLC
PARCEL : 11-0651- - -0057- -88-
APPL NUMBER: 06-50014287 CP NEW RESIDENTIAL (SFD)

SUBDIV: PLTN VINEYARD GREEN
PHONE : (910) 892-9299
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	4/26/10 5/21/10 5/21/10	AP JM AP	T/S: 04/23/2010 02:21 PM NTART √ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001931617 T/S: 05/24/2010 09:20 AM SSTEWARD T/S: 05/24/2010 09:20 AM SSTEWARD
R429 01	6/15/10 6/15/10	VC CA	FOUR TRADE FINAL VRU #: 001940899 T/S: 06/15/2010 08:01 AM VBROWN KEVIN DAUGHTRY CALLED AND CAN 4 TRADE FIN.
R429 02	6/16/10 6/18/10	KS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 001941087 T/S: 06/15/2010 08:02 AM VBROWN CUSTOMER REQUEST PM INSP. Need receptacle at end of penninsula Need tempered glass at rear door.
R229 01	6/21/10 <u>6-21</u>	TI <u>AP</u>	T/S: 06/18/2010 07:33 AM KSLATTUM TWO TRADE FINAL TIME: 17:00 VRU #: 001943539 T/S: 06/18/2010 01:36 PM JBROCK

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ✓ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: Signature Home Builders

Address: 24 Coco Drive
Lillington, NC

Permit Numbers

Building: 06-50014287
Electrical: 06-50014287
Insulation: 06-50014287
Plumbing: 06-50014287
Mechanical: 0650014287
MFG Home: _____

Date: 6-21-10

Building Official: Keith L. Stott