

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 7-10%	0-17	G SL	VFR NS/AP					PS .3
		17-26	SBX SCL	FR SS/SP					
		26-43"	SBX CL	FR S/P					
		0-6	G SL						PS .25
		6-23	SBK SCL	F SP					
		28"	LSO/P						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	250/180	LPE
Site LTAR	.3	.25

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: OT  
 Others Present: \_\_\_\_\_

4 x 75' @ 24"