

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: *06500 NY 78*

Applicant:

Address:

Date Evaluated: *04-05-06*

Proposed Facility: *Home*

Design Flow (.1949): *480*

Property Size: *.78*

Location of Site: *1125*

Property Recorded: *unr*

Water Supply:  Public     Individual     Well     Spring     Other

Evaluation Method:  Auger Boring     Pit     Cut

Type of Wastewater:  Sewage     Industrial Process     Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>342</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>348</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>342</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>342</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>342</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>
		<i>030</i>	<i>GR SL</i>	<i>VFR SE</i>					
		<i>342</i>	<i>SDH SL</i>	<i>FR SE</i>		<i>48</i>			<i>.5</i>

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	<i>Ground</i>	<i>(28)</i>
Site LTAR	<i>.5</i>	<i>.5</i>

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): *1*  
 Evaluated By: *[Signature]*  
 Others Present:

*Change to 25% Red. System 2  
 for spec*

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).

