

HTE # 06-5021452

NETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

18588

OPERATIONS PERMIT

Name: (owner) JASON PRICE CARL New Installation Septic Tank Repair

Property Location: SR# 1108 Nitrification Line Expansion
Subdivision Yorkline Lot # 174 Tax ID # _____ Quadrant # _____

Contractor: Ted Brown Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community
Distance From Well: _____ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other 25% reduction system 2 in. dia. 4 ft. h

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 100 ft. width of ditches 7 ft. depth of ditches 18-24 in.

French Drain Required: _____ Linear feet 100 Date: 08-21-06

PERMIT NO. _____ Inspected by: [Signature]

