

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500 14541

Applicant:

Address:

Date Evaluated:

Proposed Facility: Home

Design Flow (.1949): 260

Property Size: .37

Location of Site: 1108

Property Recorded: unh

Water Supply:  Public     Individual     Well     Spring     Other  
 Evaluation Method:  Auger Boring     Pit     Cut  
 Type of Wastewater:  Sewage     Industrial Process     Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	GR SL	VFR JE					
		2441	SDHJCL	FR JL		4B			.5
		024	GR SL	VFR JE					
		2442	SDHJCL	FR JE		4B			.5
		024	GR SL	VFR SE					
		2443	SDHJCL	FR JL		4B			.5
		024	GR SL	VFR JE					
		2444	SDHJCL	FR JL		4B			.5
		024	GR SL	VFR JE					
		2445	SDHJCL	FR JL		4B			.5

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
System Type(s)	Gravel	LF
Site LTAR	.5	.25

1x240  
290 LF  
4x75

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): P1  
 Evaluated By: 928  
 Others Present: ST


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



(#####)



CHECKMATE COURT

SITE PLAN APPROVAL  
 DISTRICT RAOR USE SFD  
 DISTRICT OMS 3  
William A. Duggan  
 Zoning Administrator

**S & K HOMES**  
**LOT #106 YORKSHIRE PLANTATION**  
**THE GRANT WITH SUNROOM**  
**SCALE: 1"=40'**

Permit Copy