

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500 14542

Applicant:

Address:

Date Evaluated:

Proposed Facility: Home

Design Flow (.1949): 360

Property Size: .38 ac

Location of Site: 1128

Property Recorded: unkn

Water Supply: Public [] Individual [] Well [] Spring [] Other
 Evaluation Method: Auger Boring [] Pit [] Cut
 Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	BRSL	VFA J ₂					
		2443	SDHJCL	FR J ₂		43			5
		024	GRJL	VFA J ₂					
		2443	SDHJCL	FR J ₂		48			5
		024	GRSL	VFA J ₂					
		2443	SDHJCL	FR J ₂		48			5
		024	GRJL	VFA J ₂					
		2443	SDHJCL	FR J ₂		48			5
		024	GRJL	VFA J ₂					
		2443	SDHJCL	FR J ₂		48			5

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Gravel	LPP
Site LTAR	.5	.25

1x25/0
1x24

290 LF
4975

Other Factors (.1946): _____
 Site Classification (.1948): 81
 Evaluated By: [Signature]
 Others Present: [Signature]


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE	IV	CL-CLAY LOAM	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SIC-SILTY CLAY		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
FP-FLOOD PLAN		C-CLAY			SP-SLIGHTLY STICKY
		SC-SANDY CLAY			P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE PLAN APPROVAL

DISTRICT ~~REAR~~ USE SFD

PERMIT # 3

4/11/2010 A. Druggins
Zoning Administrator



CHECKMATE COURT

S & K HOMES
THE MANCHESTER
LOT #107 YORKSHIRE PLANTATION
SCALE: 1"=40'

Permit Copy