

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500-14546

Applicant:

Date Evaluated: 4-18-05

Property Size: 1.76 ac

Property Recorded: 10/1/04

Address:

Proposed Facility: Home

Design Flow (.1949): 760

Location of Site: 1108

- Water Supply:  Public     Individual     Well     Spring     Other  
 Evaluation Method:  Auger Boring     Pit     Cut  
 Type of Wastewater:  Sewage     Industrial Process     Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	GR JL	VFA JE					
		2448	SDH JCL	FA JE		42			.5
		024	GR JL	VFA JE					
		2448	SDH JCL	FA JE		42			.5
		024	GR JL	VFA JE					
		2448	SDH JCL	FA JE		42			.5
		024	GR JL	VFA JE					
		2448	SDH JCL	FA JE		46			.5
		024	GR JL	VFA JE					
		2448	SDH JCL	FA JE		42			.5

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Gravel	LP
Site LTAR	.5	.5

1x240  
18-21      290 LF  
4x75

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): P1  
 Evaluated By: GUB  
 Others Present: SJ


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_


<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SIC-SILTY CLAY			
FP-FLOOD PLAN	IV	C-CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	VS-VERY STICKY
		SC-SANDY CLAY			NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).





COUNTIES

682  
LPA  
BRAIN

WESSEX COURT

**S & K HOMES  
THE NEWPORT  
LOT # 135 YORKSHIRE PLANTATION  
SCALE: 1"=40'**

Permit Copy

THE PLAN APPROVAL  
DISTRICT RECORD USE SFD  
SMS ~~ANALYSIS~~ 3  
Elizabeth A. Duggan