

HTE # 06-50014563

HARN COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

18583

OPERATIONS PERMIT

Name: (owner) Danny Norris (Silverado Home) New Installation Septic Tank Repair

Property Location: SR# 1108 Nitrification Line Expansion
Subdivision Yorkshire Plant Lot # 74 Tax ID # _____ Quadrant # _____

Contractor: Ted Brown Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other 25% Reduction System in Alternator Quick 4

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain Required: _____ Linear feet 4 chambers Date: 8-24-06

PERMIT NO. 22646 Inspected by: J. [Signature]

M.C.P. 100
S.D. 814
6-23-06

