

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06.500/4619

Applicant:

Date Evaluated: 5-1-06

Address:

Property Size: .37 AC

Proposed Facility: Home

Design Flow (.1949): 360

Location of Site: 1103

Property Recorded: unk

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		024	GR SL	VFA JE					
		2443	SDH SCL	FA JE		48			.5
		024	GR SL	VFA JE					
		2443	SDH SCL	FA JE		48			.5
		024	GR SL	VFA JE					
		2443	SDH SCL	FA JE		48			.5
		024	GR SL	VFA JE					
		2443	SDH SCL	FA JE		48			.5
		024	GR SL	VFA JE					
		2443	SDH SCL	FA JE		48			.5

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	Gravel	UP
Site LTAR	.5	.25

12242
13.22

290LF
4x75

Other Factors (.1946): _____
 Site Classification (.1948): P
 Evaluated By: JW
 Others Present: KP


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1	VFI-VERY FIRM	VS-VERY STICKY
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			
		SICL-SILTY CLAY LOAM		EFI-EXTREMELY FIRM	NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




SITE PLAN APPROVAL

DISTRICT BAZOR USE SFD

#BEDROOMS 3

Date 4/19/06 QAB
Zoning Administrator

1" = 30'



P+S Homebuilders LLC.

Lot # 108 YORKSHIRE PLANTATION
CHECKMATE COURT