

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: _____ Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0-10	G LS	VF2 NS/NP					PS .3
		10-27	SBK C	F S/P					
		27"	PM(?)	MATERIAL GROUND UP IN AUGER					
		0-12"	G LS	VF2 NS/NP					PS .7
		12-32"	SBK C	FR SB/P					
		32"	PM						
		0-12"	G LS	VF2 NS/NP					PS .3
		12-30"	SBK C	F S/P					
		30"	PM						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	PM IN REPAIR	= REPAIR
Site LTAR	.3	.3

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: JT
 Others Present: _____