

HTE# 06-5-14763

# IMPROVEMENT PERMIT 22973

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MALAKA VENTURES LLC New Installation  Septic Tank  Repair   
Property Location: SR# 1437 BALLARD RD Nitrification Line  Expansion   
Subdivision BALLARD WOODS Lot # 59  
Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Number of Bedrooms Proposed: 3 (360 sqd) Lot Size: .574 AC

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property.  
**Subject to final approval.**

Type of system:  Conventional  Other Pump To 25% REDUCTION  
Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface No. of exact length width of depth of  
Drainage Field ditches 1 of each ditch 300 ft. ditches 3 ft. ditches 18-20 in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 5/22/06  
**PERMIT EXPIRES 5 YEARS FROM ABOVE DATE**

**This permit is subject to revocation if site plans or intended use change.**

Signed: [Signature] ES (OLIVER TOLKSDORF)  
Environmental Health Specialist

\* MAINTAIN ALL SETBACKS  
\* CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 22973. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

MALAKA VENTURES LLC 919-524-2915  
Name Telephone #

PO Box 655 HOLLY SPRINGS NC 27540  
Address

1437 BALLARD RD  
Property Location SR# Road Name

BALLARD WOODS 59 3 (360 sq ft) .574 ac  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation [ ] Repair  Septic Tank  Nitrification Lines  
[ ] Conventional  Other Volume To 25% Reduction  
[ ] Basement [ ] With Plumbing [ ] Without Plumbing  
Water Supply: [ ] Well  Public Water Supply Minimum Well Setback: 100 Ft.  
Septic Tank 1000 gal Pump Chamber 1000 gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 1 Length of lines 300 Ft.  
Width of ditches 3 ft. Depth of ditches 18-20 inches  
French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] RS 5/22/06  
Signature of Authorized Agent for Harnett County Date