

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500 14817

Applicant:

Date Evaluated: 5-17-06

Address:

Property Size: .35

Proposed Facility: H₂O

Design Flow (.1949): 760

Property Recorded: wk

Location of Site: 1108

Water Supply: Public [] Individual [] Well [] Spring [] Other

Evaluation Method: Auger Boring [] Pit [] Cut

Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		042	GR SL	VFA S ₂		42			6
		042	GR SL	VFA S ₂		42			6
		042	GR SL	VFA S ₂		42			6
		042	GR SL	VFA S ₂		42			6
		042	GR SL	VFA S ₂		42			6

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	Grass	WSP
Site LTAR	6	6

Other Factors (.1946): _____

Site Classification (.1948): 6/6

Evaluated By: [Signature]

Others Present: [Signature]

1200


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



1" = 20'



SITE PLAN APPROVAL
DISTRICT RA20R USE SFD
#BEDROOMS 3
5/9/06 AB
Date Zoning Administrator

Wm Kent Pierce, Inc.
Lot # 162 Yorkshire Plantation
59 Gloucester Court