

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06-500 14851

Applicant:

Date Evaluated: 05-17-06

Address:

Property Size: 1.35

Proposed Facility: home

Design Flow (.1949): 360

Property Recorded: mt

Location of Site: 1100

- Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
		038	GR SL	VFA S <sub>2</sub>			40			.55
		3846	SM SL	FA S <sub>2</sub>						
		038	GR SL	VFA S <sub>2</sub>			40			.55
		3846	SM SL	FA S <sub>2</sub>						
		040	GR SL	VFA S <sub>2</sub>			40			.55
		3846	SM SL	FA S <sub>2</sub>						
		040	GR SL	VFA S <sub>2</sub>			40			.55
		3846	SM SL	FA S <sub>2</sub>						
		040	GR SL	VFA S <sub>2</sub>			40			.55
		3846	SM SL	FA S <sub>2</sub>						

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	CAAS	LA
Site LTAR	.55	

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): P)  
 Evaluated By: JW  
 Others Present: KP

220 with ref. to spec spec


COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE  
 SG-SINGLE GRAIN  
 M-MASSIVE  
 CR-CRUMB  
 GR-GRANULAR  
 SBK-SUBANGULAR BLOCKY  
 ABK-ANGULAR BLOCKY  
 PL-PLATY  
 PR-PRISMATIC

MINERALOGY  
 SLIGHTLY EXPANSIVE  
 EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).





LDS Homes LLC  
 Lot # 113 Yorkshire Plantation  
 15 Wessex Court

520  
 out plan  
 at 520  
 h.h.



met  
 out

SITE PLAN APPROVAL  
 DISTRICT RA2013 USE 3  
 #BEDROOMS 3  
 Date 5/10/10  
 Zoning Administrator [Signature]

1" = 30'