

COMMENTS:

5/3/2017 Recived a call from Larry Sharpe he stated that second stepdown in the drain line had been crushed. He fixed that + the system is now working ~~proably~~ properly.