

HTE# 06.50015041RR

Harris County Department of Public Health

23812

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Southeastern Properties PROPERTY LOCATION: 1201
 SUBDIVISION CAROLINA SEASONS LOT # D-9
 NEW ☒ REPAIR ☐ EXPANSION ☐ Site Improvements required prior to Construction Authorization Issuance:
 Type of Structure: SFD 48x61 3BR
 Proposed Wastewater System Type: Pump to 25% Reduction system
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement ☐ Yes ☒ No
 Pump Required: ☒ Yes ☐ No ☐ May be required based on final location and elevations of facilities
 Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 50 feet Permit valid for: ☒ Five years
 Permit conditions: met on site - All parts of septic system must
Be 50' from Pond - Tanks included. maintain all set backs ☐ No expiration

Authorized State Agent: J. W. A. S. I. Date: 03-22-07 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Southeastern Properties PROPERTY LOCATION: 1201
 SUBDIVISION CAROLINA SEASONS LOT # D-9
 Facility Type: SFD- 48x61 - 3BR ☒ New ☐ Expansion ☐ Repair
 Basement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☒ No
 Type of Wastewater System** Pump to 25% Red. sys. (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable ☒ Pump to 25% Red. sys. (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x300 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 max inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. A. S. I. Date: 03-22-07 SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 03-22-2012


HTE# 0650015041RR

Permit # 23812

Harnett County Department of Public Health Site Sketch

ISSUED TO: Southeastern Property PROPERTY LOCATION: 1201
SUBDIVISION: CAROLINA SEASONS LOT # D-9
Authorized State Agent: Joe Lutz RS Date: 3-22-07

Pond



Meet onsite for Final Layout

MAINTAIN ALL SET BACKS

All Parts of septic system must Be 50' from pond
Tanks included. See Consultants layout for exact
MEASUREMENTS.