



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

June 27, 2006

Southeastern Properties
P O Box 639
Olivia, NC 28368

Re: Status of Improvement Permit Application #06-5-15041R

Dear To Whom It May Concern,

On June 26, 2006, an Environmental Health Specialist from the Harnett County Health Department attempted to evaluate your property for the purpose of issuing an Improvement Permit. This individual was unable to evaluate your property for one or more of the following reasons.

- ☒ 1. Property lines/corners not marked or labeled – **Have surveyor locate irons and flag side lines.**
- ☐ 2. House corners not marked or labeled
- ☐ 3. Directions not clear to property
- ☒ 4. Property needs brush or vegetation removed
- ☐ 5. Backhoe pits required
- ☒ 6. Other – **See page 2**

Steel
NCL

When you have completed this, please call 910-893-7527 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.


Sincerely,

Joe West, R.S.
Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting

1st
Chye P
South 70R
30x60
now here





Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

I need the following items completed so that I may finish my soil evaluation:

- 1) Surveyor must locate all property corners (true irons) and flag all property lines.
- 2) Clear underbrush from lot so that I may do septic system and repair layout.
- 3) You need to know that the house location, house size, (less than 4 bedrooms), may need to change to fit lot and soil conditions on lot. Septic system has to be 50' from high water mark of the pond. Septic system may require the use of pump, and an alternative type system.
- 4) If you have questions about what I need to have done please call me at 910-893-7547



Harnett
COUNTY
NORTH CAROLINA

Department of Public Health

www.harnett.org

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

September 21, 2006

Southeastern Properties
P O Box 639
Olivia, NC 28368

Re: Status of Improvement Permit Application #06-5-15041R

Dear To Whom It May Concern,

On September 20, 2006, an Environmental Health Specialist from the Harnett County Health Department attempted to evaluate your property for the purpose of issuing an Improvement Permit. This individual was unable to evaluate your property for one or more of the following reasons.

- _____ 1. Property lines/corners not marked or labeled
- _____ 2. House corners not marked or labeled
- _____ 3. Directions not clear to property
- _____ 4. Property needs brush or vegetation removed
- _____ 5. Backhoe pits required
- _____ 6. Other – You will need to move house as shown on the attached sheet and reduce the size of the house to 30 x 55 and the number of bedrooms to 3. Please submit new plot plan to Central Permitting so that I can issue a permit for you.

When you have completed this, please call 910-893-7527 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting

Southeastern Properties
Lot D-9 Carolina Seawalls
06-50015041 R

NOT TO
Scale

