

06-5-15849

HARNETT COUNTY HEALTH DEPARTMENT

No 14346

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) MARSHALL JOHNSON CONSTRUCTION INC New Installation Septic Tank
Property Location: SR# 1703 RED HILL CH RD Repairs Nitrification Line

Subdivision CANE MEAN ESTATES Lot # 9

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 BRN 480GPD Lot Size: 1.63 ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other 25% Reduction System

Size of tank: Septic Tank: 1200 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 2 exact length of each ditch 200 ft. width of ditches 3 ft. depth of ditches 22-1/2 in.

French Drain Required: _____ Linear feet

Date: James E. Markham
Signed: 6-23-06

This permit is subject to revocation if site plans or intended use change.

Environmental Health Specialist



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 14346. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Marshall Johnson Construction, Inc Telephone # 919-894-2064

Address 283 Banner Bk Rd Benson N.C.

Property Location SR# 1703 Road Name Red Hill Ch Rd

Subdivision CANE MELL EST Lot # 9 # Bedrooms Proposed 4 BR - 4 BOD Lot Size .63

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other 25% Red System

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: _____ Ft.

Septic Tank 1200 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 2 Length of lines 200 Ft.

Width of ditches 3 ft. Depth of ditches 22" to 12" inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Markant
Signature of Authorized Agent for Harnett County

6-23-06
Date