

PREPARED 7/14/06, 8:32:00  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 1  
DATE 7/13/06

ADDRESS . : LAND FILE ISSUE SUBDIV:  
CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
OWNER . . : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
PARCEL . . : - - - - -  
APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
10 MILES TURN RIGHT ONTO BILL SHAW RD  
TO CROSSROAD LEFT ONTO OVERHILLS RD  
LEFT AT SIERRA TRAIL LEFT AT NORTH  
DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06 <u>7/13/06</u>	TI <u>APICE</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783

COMMENTS AND NOTES

ADDRESS : LAND FILE ISSUE SUBDIV:  
 CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
 OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
 PARCEL : - - - - -  
 APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
 10 MILES TURN RIGHT ONTO BILL SHAW RD  
 TO CROSSROAD LEFT ONTO OVERHILLS RD  
 LEFT AT SIERRA TRAIL LEFT AT NORTH  
 DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101.01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207.01	7/19/06 <i>7/19/06</i>	TI <i>APKE</i>	R*ELEC TEMP SERVICE POLE VRU #: 001237874 TSP DID NOT PASS ON FOOTING AND FOUND.

----- COMMENTS AND NOTES -----

*893-7547  
Braham*

ADDRESS : 49 NORTH DAKOTA CT  
CONTRACTOR : SHAW CONSTRUCTION CO, INC.  
OWNER : SHAW CONSTRUCTION CO INC #3  
PARCEL : 01-0536-01- -0111- -02-  
APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
10 MILES TURN RIGHT ONTO BILL SHAW RD  
TO CROSSROAD LEFT ONTO OVERHILLS RD  
LEFT AT SIERRA TRAIL LEFT AT NORTH  
DAKOTA LOT ON LEFT. -A.DRIGGERS

SUBDIV: SIERRA VILLAGE@OVERHILLS  
PHONE :  
PHONE : (910) 483-2904

STRUCTURE: 000 000 36X66 4BR SFD  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476

*AP map*

COMMENTS AND NOTES

ADDRESS : 49 NORTH DAKOTA CT SUBDIV: SIERRA VILLAGE@OVERHILLS  
CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
PARCEL : 01-0536-01- -0111- -02-  
APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
10 MILES TURN RIGHT ONTO BILL SHAW RD  
TO CROSSROAD LEFT ONTO OVERHILLS RD  
LEFT AT SIERRA TRAIL LEFT AT NORTH  
DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	TI	R*OPEN FLOOR VRU #: 001264001

8-29-6 AP-CE

COMMENTS AND NOTES

-----  
ADDRESS : 49 NORTH DAKOTA CT SUBDIV: SIERRA VILLAGE@OVERHILLS  
CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
PARCEL : 01-0536-01- -0111- -02-  
APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
10 MILES TURN RIGHT ONTO BILL SHAW RD  
TO CROSSROAD LEFT ONTO OVERHILLS RD  
LEFT AT SIERRA TRAIL LEFT AT NORTH  
DAKOTA LOT ON LEFT. -A.DRIGGERS  
-----

STRUCTURE: 000 000 36X66 4BR SFD  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	CE	R*OPEN FLOOR VRU #: 001264001
	8/29/06	AP	
R427 01	10/04/06	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001282912

10-4-6 AP-CE

----- COMMENTS AND NOTES -----

ADDRESS : 49 NORTH DAKOTA CT  
 CONTRACTOR : SHAW CONSTRUCTION CO, INC.  
 OWNER : SHAW CONSTRUCTION CO INC #3  
 PARCEL : 01-0536-01- -0111- -02-  
 APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
 10 MILES TURN RIGHT ONTO BILL SHAW RD  
 TO CROSSROAD LEFT ONTO OVERHILLS RD  
 LEFT AT SIERRA TRAIL LEFT AT NORTH  
 DAKOTA LOT ON LEFT. -A.DRIGGERS

SUBDIV: SIERRA VILLAGE@OVERHILLS  
 PHONE :  
 PHONE : (910) 483-2904

*Handwritten:* To Sierra Trail  
 Left Dakota

STRUCTURE: 000 000 36X66 4BR SFD  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	CE	R*OPEN FLOOR VRU #: 001264001
	8/29/06	AP	
R427 01	10/04/06	CE	FOUR TRADE ROUGH IN >2500 VRU #: 001282912
	10/04/06	AP	
I129 01	10/06/06	TI	R*INSULATION INSPECTION VRU #: 001286814

*Handwritten:* DAK

COMMENTS AND NOTES



ADDRESS : 49 NORTH DAKOTA CT SUBDIV: SIERRA VILLAGE@OVERHILLS  
 CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
 OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
 PARCEL : 01-0536-01- -0111- -02-  
 APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
 10 MILES TURN RIGHT ONTO BILL SHAW RD  
 TO CROSSROAD LEFT ONTO OVERHILLS RD  
 LEFT AT SIERRA TRAIL LEFT AT NORTH  
 DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	CE	R*OPEN FLOOR VRU #: 001264001
	8/29/06	AP	
R427 01	10/04/06	CE	FOUR TRADE ROUGH IN >2500 VRU #: 001282912
	10/04/06	AP	
I129 01	10/06/06	TI	R*INSULATION INSPECTION VRU #: 001286814
	10/06/06	DA	not ready
I129 02	10/10/06	TI	R*INSULATION INSPECTION VRU #: 001288430

10-10-6 AP-CE

COMMENTS AND NOTES



ADDRESS : 49 NORTH DAKOTA CT SUBDIV: SIERRA VILLAGE@OVERHILLS  
CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
PARCEL : 01-0536-01- -0111- -02-  
APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : SIERRA VILLAGE LOT 3. NC 210S APPROX  
10 MILES TURN RIGHT ONTO BILL SHAW RD  
TO CROSSROAD LEFT ONTO OVERHILLS RD  
LEFT AT SIERRA TRAIL LEFT AT NORTH  
DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	✓49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	CE	R*OPEN FLOOR VRU #: 001264001
	8/29/06	AP	
R427 01	10/04/06	CE	FOUR TRADE ROUGH IN >2500 VRU #: 001282912
	10/04/06	AP	
I129 01	10/06/06	KT	R*INSULATION INSPECTION VRU #: 001286814
	10/06/06	DA	not ready
I129 02	10/10/06	CE	R*INSULATION INSPECTION VRU #: 001288430
	10/10/06	AP	
H824 01	12/06/06	BM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001319482
	12/06/06	AP	
R429 01	1/29/07	TI	FOUR TRADE FINAL VRU #: 001344218
	1/26/07	CA	
R429 02	1/30/07	TI	FOUR TRADE FINAL VRU #: 001344931

1-30-07 DA/CE

COMMENTS AND NOTES

**DO NOT REMOVE!**

**Harnett County Inspection Department**

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: BILL SHAW CONSTRUCTION Date: 1-30-07

Address: 49 North Dakota

Lot No.: #3 Permit No.: 06-50015079

(Check Box for Violation)

- |                                     |                                     |                                  |  |                                     |                                       |                                 |                                      |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing    | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg.   | <input type="checkbox"/> Elec.             | <input type="checkbox"/> Plumb.     | <input type="checkbox"/> Mech.        | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home  | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other  |                                      |

Violations Found: FINALS D/A

- ① Install exhaust vent covers in soffitt
- ② Replace brick in garage steps
- ③ Secure jacuzzi recept. box under tub
- ④ clean debris from under house
- ⑤ Cut clean-out to grade

Code Enforcement Official C. Edgerth Date: 1-30-07  
Signature \_\_\_\_\_

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 49 NORTH DAKOTA CT SUBDIV: SIERRA VILLAGE@OVERHILLS  
 CONTRACTOR : SHAW CONSTRUCTION CO, INC. PHONE :  
 OWNER : SHAW CONSTRUCTION CO INC #3 PHONE : (910) 483-2904  
 PARCEL : 01-0536-01- -0111- -02-  
 APPL NUMBER: 06-50015079 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : SIERRA VILLAGE LOT 3, NC 210S APPROX  
 10 MILES TURN RIGHT ONTO BILL SHAW RD  
 TO CROSSROAD LEFT ONTO OVERHILLS RD  
 LEFT AT SIERRA TRAIL LEFT AT NORTH  
 DAKOTA LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 36X66 4BR SFD  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/13/06	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001234783
	7/14/06	AP	T-POLE D/A. DRIVE GROUND ROD TO GRADE. CE
E207 01	7/19/06	CE	R*ELEC TEMP SERVICE POLE VRU #: 001237874
	7/19/06	AP	TSP DID NOT PASS ON FOOTING AND FOUND.
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242765
	7/27/06	CA	
B103 02	8/03/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001247476
	8/03/06	AP	
A814 03	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263995
	8/28/06	CA	
A814 02	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263987
	8/28/06	CA	
A814 01	8/29/06	TI	ADDRESS CONFIRMATION VRU #: 001263979
	8/28/06	AP	✓ 49 NORTH DAKOTA CT LOT 3
B105 01	8/29/06	CE	R*OPEN FLOOR VRU #: 001264001
	8/29/06	AP	
R427 01	10/04/06	CE	FOUR TRADE ROUGH IN >2500 VRU #: 001282912
	10/04/06	AP	
I129 01	10/06/06	KT	R*INSULATION INSPECTION VRU #: 001286814
	10/06/06	DA	not ready
I129 02	10/10/06	CE	R*INSULATION INSPECTION VRU #: 001288430
	10/10/06	AP	
H824 01	12/06/06	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001319482
	12/06/06	AP	
R429 01	1/29/07	TI	✓ FOUR TRADE FINAL VRU #: 001344218
	1/26/07	CA	
R429 02	1/30/07	CE	FOUR TRADE FINAL VRU #: 001344931
	1/30/07	DA	1) install exhaust vent covers in soffitts 2) replace brick in garage steps 3) secure jacuzzi receptacle box 4) clean debris from under house 5) cut clean-out to grade
R429 03	2/02/07	TI	FOUR TRADE FINAL VRU #: 001347028

2-2-7 AP-CE

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Res. SFD

Conditional Use Permit No.: —

Type of Construction: —

Building Permit No.: 06-50015079

Owner of Building: SHAW CONSTR.

Electrical Permit No.: 1

Building Address: 49 North Dakota

Insulation Permit No.: —

Zoning District: —

Plumbing Permit No.: 11

Zoning Permit No.: —

Mech. Permit No.: 1

Date: 2-2-07

Envir. C.O. No.: —

C. Edge  
Building Official

—  
Zoning Official