



Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

February 12, 2007

Jason Price Construction
121 Green Forest Circle
Dunn, NC 28334

Re: Status of Improvement Permit Application #06-5-15153RR Lt 46 Laurel Valley

Dear To Whom It May Concern,

An Environmental Health Specialist from the Harnett County Health Department attempted to evaluate your property for the purpose of issuing an Improvement Permit. This individual was unable to evaluate your property for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. Other – **Your consultant's layout and house placement has home at least 40' from side line not 27' as shown on your plot plan. Please move home so that it is 40' from property line and resubmit as a revision to Central Permitting.**

When you have completed this, please call 910-893-7527 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/sgs

Copy: Central Permitting