
ADDRESS . : 91 SCARLET OAK CIR
CONTRACTOR : CEBCO CONST INC
OWNER . . : KENNETH CUMMINGS LLC #84
PARCEL . . : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	TI <i>AP MR</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561

COMMENTS AND NOTES

ADDRESS . : 91 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2
CONTRACTOR : CEBCO CONST INC PHONE :
OWNER . . : KENNETH CUMMINGS LLC #84 PHONE : (910) 893-5826
PARCEL . . : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336

_____ *Ap-mjt*

----- COMMENTS AND NOTES -----

ADDRESS : 91 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2
 CONTRACTOR : CEBCO CONST INC PHONE :
 OWNER : KENNETH CUMMINGS LLC #84 PHONE : (910) 893-5826
 PARCEL : 01-0536-02- -0028- -84-
 APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
 LEFT LEMUEL TURN LEFT FOREST OAKS TURN
 RIGHT SCARLET OAK CIR LOT ON LEFT LOT
 84 JB

STRUCTURE: 000 000 32X50 3BDR
 FLOOD ZONE : FLOOD ZONE X
 BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

APP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
105 01	8/01/06	TI	R*OPEN FLOOR VRU #: 001245860

AP - mjc

COMMENTS AND NOTES

ADDRESS : 91 SCARLET OAK CIR
CONTRACTOR : CEBCO CONST INC
OWNER : KENNETH CUMMINGS LLC #84
PARCEL : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

SUBDIV: FOREST OAKS PH 1 & 2
PHONE :
PHONE : (910) 893-5826

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
B105 01	8/01/06	MR	R*OPEN FLOOR VRU #: 001245860
	8/01/06	AP	
A814 01	8/25/06	TI	ADDRESS CONFIRMATION VRU #: 001262914
R427 01	8/25/06	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001262922

PA-MR

COMMENTS AND NOTES

ADDRESS : 91 SCARLET OAK CIR
CONTRACTOR : CEBCO CONST INC
OWNER : KENNETH CUMMINGS LLC #84
PARCEL : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

SUBDIV: FOREST OAKS PH 1 & 2
PHONE :
PHONE : (910) 893-5826

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
B105 01	8/01/06	MR	R*OPEN FLOOR VRU #: 001245860
	8/01/06	AP	
A814 01	8/25/06	TI	ADDRESS CONFIRMATION VRU #: 001262914
	8/25/06	AP	91 SCARLET OAK CIR LOT 84
R427 01	8/25/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001262922
	8/25/06	DA	outlets missing in kitcen area dining circuit is to be 20 amp low volt for alarm not to be on washer circuit outlet spacing upstairs bedroom brace gables run gas line to outside and install test ok to insulate and side
I129 01	8/31/06	TI	R*INSULATION INSPECTION VRU #: 001266524
		<i>AP-IVR</i>	
R425 01	8/31/06	TI	FOUR TRADE ROUGH IN VRU #: 001266533
		<i>AP-IVR</i>	

COMMENTS AND NOTES

ADDRESS : 91 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2
CONTRACTOR : CEBCO CONST INC PHONE :
OWNER : KENNETH CUMMINGS LLC #84 PHONE : (910) 893-5826
PARCEL : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
B105 01	8/01/06	MR	R*OPEN FLOOR VRU #: 001245860
	8/01/06	AP	
A814 01	8/25/06	TI	ADDRESS CONFIRMATION VRU #: 001262914
	8/25/06	AP	91 SCARLET OAK CIR LOT 84
R427 01	8/25/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001262922
	8/25/06	DA	outlets missing in kitcen area dining circuit is to be 20 amp low volt for alarm not to be on washer circuit outlet spacing upstairs bedroom brace gables run gas line to outside and install test ok to insulate and side
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266524
	8/31/06	AP	
R425 01	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266533
	8/31/06	AP	
H824 01	9/18/06	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001275890
	9/18/06	AP	
R425 02	11/02/06	TI	FOUR TRADE ROUGH IN VRU #: 001302352
	11/01/06	CA	
R429 01	11/02/06	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001302645

DAWR

COMMENTS AND NOTES

A/c walkway too narrow
Lite switch in Attic
Lite in closet too close

ADDRESS . : 91 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2
CONTRACTOR : CEBCO CONST INC PHONE :
OWNER . . : KENNETH CUMMINGS LLC #84 PHONE : (910) 893-5826
PARCEL . . : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
B105 01	8/01/06	MR	R*OPEN FLOOR VRU #: 001245860
	8/01/06	AP	
A814 01	8/25/06	TI	ADDRESS CONFIRMATION VRU #: 001262914
	8/25/06	AP	91 SCARLET OAK CIR LOT 84
R427 01	8/25/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001262922
	8/25/06	DA	outlets missing in kitcen area dining circuit is to be 20 amp low volt for alarm not to be on washer circuit outlet spacing upstairs bedroom brace gables run gas line to outside and install test ok to insulate and side
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266524
	8/31/06	AP	
R425 01	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266533
	8/31/06	AP	
H824 01	9/18/06	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001275890
	9/18/06	AP	
R425 02	11/02/06	TI	FOUR TRADE ROUGH IN VRU #: 001302352
	11/01/06	CA	a/c walkway too small lite switch in attic lite in closet too close
R429 01	11/02/06	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 001302645
	11/02/06	DA	walkway too small on ahu lite switch needed on attic light lite in attic too close
R425 03	11/06/06	TI	FOUR TRADE ROUGH IN VRU #: 001303743
	11/06/06	CA	
R429 02	11/06/06	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001304567

AP-MIR

----- COMMENTS AND NOTES -----

ADDRESS : 91 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2
CONTRACTOR : CEBCO CONST INC PHONE :
OWNER : KENNETH CUMMINGS LLC #84 PHONE : (910) 893-5826
PARCEL : 01-0536-02- -0028- -84-
APPL NUMBER: 06-50015193 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN
LEFT LEMUEL TURN LEFT FOREST OAKS TURN
RIGHT SCARLET OAK CIR LOT ON LEFT LOT
84 JB

STRUCTURE: 000 000 32X50 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232561
	7/11/06	AP	
B103 01	7/27/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001243336
	7/27/06	AP	
B105 01	8/01/06	MR	R*OPEN FLOOR VRU #: 001245860
	8/01/06	AP	
A814 01	8/25/06	TI	ADDRESS CONFIRMATION VRU #: 001262914
	8/25/06	AP	✓ 91 SCARLET OAK CIR LOT 84
R427 01	8/25/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001262922
	8/25/06	DA	outlets missing in kitcen area dining circuit is to be 20 amp low volt for alarm not to be on washer circuit outlet spacing upstairs bedroom brace gables run gas line to outside and install test ok to insulate and side
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266524
	8/31/06	AP	
R425 01	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266533
	8/31/06	AP	
H824 01	9/18/06	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001275890
	9/18/06	AP	
R425 02	11/02/06	TI	FOUR TRADE ROUGH IN VRU #: 001302352
	11/01/06	CA	a/c walkway too small lite switch in attic lite in closet too close
R429 01	11/02/06	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 001302645
	11/02/06	DA	walkway too small on ahu lite switch needed on attic light lite in attic too close
R425 03	11/06/06	TI	FOUR TRADE ROUGH IN VRU #: 001303743

AP-MIC

Final

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Res.

Type of Construction: II

Owner of Building: Cebco

Building Address: 91 Scarlett Oak

Zoning District: _____

Zoning Permit No.: _____

Date: 11-3-6

M. R. Reasie
Building Official

Conditional Use Permit No.: _____

Building Permit No.: 06-50015193

Electrical Permit No.: 11

Insulation Permit No.: 11

Plumbing Permit No.: 11

Mech. Permit No.: 11

Envir. C.O. No.: _____

Zoning Official