

ADDRESS : 91 SCARLET OAK CIR  
CONTRACTOR : CEBCO CONST INC  
OWNER : KENNETH CUMMINGS LLC #85  
PARCEL : 01-0536-02- -0028- -84-  
APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
85 JB

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE :  
PHONE : (910) 893-5826

STRUCTURE: 000 000 52X58 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	TI <i>AP - MK</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589

COMMENTS AND NOTES



ADDRESS . : 81 SCARLET OAK CIR  
CONTRACTOR : CEBCO CONST INC  
OWNER . . : KENNETH CUMMINGS LLC #85  
PARCEL . . : 01-0536-02- -0028- -85-  
APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
85 JB

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE :  
PHONE : (910) 893-5826

STRUCTURE: 000 000 52X58 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	TI	R*OPEN FLOOR VRU #: 001244326

*AP-MR*

COMMENTS AND NOTES

ADDRESS . : 81 SCARLET OAK CIR  
CONTRACTOR : CEBCO CONST INC  
OWNER . . : KENNETH CUMMINGS LLC #85  
PARCEL . . : 01-0536-02- -0028- -85-  
APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
85 JB

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE :  
PHONE : (910) 893-5826

STRUCTURE: 000 000 52X58 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103. 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	MR	R*OPEN FLOOR VRU #: 001244326
	7/28/06	AP	
R425. 01	8/25/06	TI	FOUR TRADE ROUGH IN VRU #: 001262760

*DA-MR*

COMMENTS AND NOTES

ADDRESS : 81 SCARLET OAK CIR  
CONTRACTOR : CEBCO CONST INC  
OWNER : KENNETH CUMMINGS LLC #85  
PARCEL : 01-0536-02- -0028- -85-  
APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
85 JB

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE :  
PHONE : (910) 893-5826

STRUCTURE: 000 000 52X58 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	MR	R*OPEN FLOOR VRU #: 001244326
	7/28/06	AP	
R425 01	8/25/06	MR	FOUR TRADE ROUGH IN VRU #: 001262760
	8/25/06	DA	wing walls in garage to be sheathed outlet missing in nook area insufficient straps on trusses b1,b2, a1 run gas line to outside and install test ok to side and insulate
A814 01	8/31/06	TI	ADDRESS CONFIRMATION VRU #: 001266568
I129 01	8/31/06	TI	R*INSULATION INSPECTION VRU #: 001266576
		<i>AP-ml</i>	
R425 02	8/31/06	TI	FOUR TRADE ROUGH IN VRU #: 001266542
		<i>AP ml</i>	

COMMENTS AND NOTES

-----

ADDRESS : 81 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2  
 CONTRACTOR : CEBCO CONST INC PHONE :  
 OWNER : KENNETH CUMMINGS LLC #85 PHONE : (910) 893-5826  
 PARCEL : 01-0536-02- -0028- -85-  
 APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
 LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
 RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
 85 JB

-----

STRUCTURE: 000 000 52X58 3BDR  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	MR	R*OPEN FLOOR VRU #: 001244326
	7/28/06	AP	
R425 01	8/25/06	MR	FOUR TRADE ROUGH IN VRU #: 001262760
	8/25/06	DA	wing walls in garage to be sheathed outlet missing in nook area insufficient straps on trusses b1,b2, a1 run gas line to outside and install test ok to side and insulate
A814 01	8/31/06	TI	ADDRESS CONFIRMATION VRU #: 001266568
	8/31/06	AP	81 SCARLET OAK CIR LOT 85
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266576
	8/31/06	AP	
R425 02	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266542
	8/31/06	AP	
H824 01	9/15/06	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001274877
	9/15/06	AP	
R429 01	11/14/06	MR	FOUR TRADE FINAL VRU #: 001306839
	11/14/06	DA	ac duct too close to ground no clear access to AHU under house per code no insulation in attic range to be on 40 amp circuit for #8 wire
R429 02	11/17/06	TI	FOUR TRADE FINAL VRU #: 001309916

DA-MG

----- COMMENTS AND NOTES -----

ADDRESS : 81 SCARLET OAK CIR  
CONTRACTOR : CEBCO CONST INC  
OWNER : KENNETH CUMMINGS LLC #85  
PARCEL : 01-0536-02- -0028- -85-  
APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
85 JB

SUBDIV: FOREST OAKS PH 1 & 2  
PHONE :  
PHONE : (910) 893-5826

STRUCTURE: 000 000 52X58 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	MR	R*OPEN FLOOR VRU #: 001244326
	7/28/06	AP	
R425 01	8/25/06	MR	FOUR TRADE ROUGH IN VRU #: 001262760
	8/25/06	DA	wing walls in garage to be sheathed outlet missing in nook area insufficient straps on trusses b1,b2, a1 run gas line to outside and install test ok to side and insulate
A814 01	8/31/06	TI	ADDRESS CONFIRMATION VRU #: 001266568
	8/31/06	AP	✓ 81 SCARLET OAK CIR LOT 85
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266576
	8/31/06	AP	
R425 02	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266542
	8/31/06	AP	
H824 01	9/15/06	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001274877
	9/15/06	AP	
R429 01	11/14/06	TI	FOUR TRADE FINAL VRU #: 001306839

DA-MR

-----COMMENTS AND NOTES-----

ADDRESS : 81 SCARLET OAK CIR SUBDIV: FOREST OAKS PH 1 & 2  
 CONTRACTOR : CEBCO CONST INC PHONE :  
 OWNER : KENNETH CUMMINGS LLC #85 PHONE : (910) 893-5826  
 PARCEL : 01-0536-02- -0028- -85-  
 APPL NUMBER: 06-50015194 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 WEST TURN LEFT ON NURSERY TURN  
 LEFT LEMUEL TURN LEFT FOREST OAKS TURN  
 RIGHT SCARLET OAK CIR LOT ON LEFT LOT  
 85 JB

STRUCTURE: 000 000 52X58 3BDR  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/11/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001232589
	7/11/06	AP	
B103 01	7/26/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001242658
	7/26/06	AP	
B105 01	7/28/06	MR	R*OPEN FLOOR VRU #: 001244326
	7/28/06	AP	
R425 01	8/25/06	MR	FOUR TRADE ROUGH IN VRU #: 001262760
	8/25/06	DA	wing walls in garage to be sheathed outlet missing in nook area insufficient straps on trusses b1,b2, a1 run gas line to outside and install test ok to side and insulate
A814 01	8/31/06	TI	ADDRESS CONFIRMATION VRU #: 001266568
	8/31/06	AP	81 SCARLET OAK CIR LOT 85
I129 01	8/31/06	MR	R*INSULATION INSPECTION VRU #: 001266576
	8/31/06	AP	
R425 02	8/31/06	MR	FOUR TRADE ROUGH IN VRU #: 001266542
	8/31/06	AP	
H824 01	9/15/06	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001274877
	9/15/06	AP	
R429 01	11/14/06	MR	FOUR TRADE FINAL VRU #: 001306839
	11/14/06	DA	ac duct too close to ground no clear access to AHU under house per code no insulation in attic range to be on 40 amp circuit for #8 wire
R429 02	11/17/06	MR	FOUR TRADE FINAL VRU #: 001309916
	11/17/06	DA	access to AHU under house not to code
R429 03	11/20/06	TI	FOUR TRADE FINAL VRU #: 001310726

COMMENTS AND NOTES



**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: \_\_\_\_\_

Type of Construction: II

Building Permit No.: 06-50015194

Owner of Building: Kenneth Cummings LLC

Electrical Permit No.: 11

Building Address: 81 Scarlett Oaks

Insulation Permit No.: 11

Zoning District: \_\_\_\_\_

Plumbing Permit No.: 11

Zoning Permit No.: \_\_\_\_\_

Mech. Permit No.: 11

Date: 11-20-06

Envir. C.O. No.: \_\_\_\_\_

M. L. Rean

Building Official

Zoning Official