

ADDRESS . : 85109 *UNASSIGNED SUBDIV:
CONTRACTOR : PHONE :
OWNER . . : ADAMS ALEX & LEIGH PHONE : (919) 639-6884
PARCEL . . : 04-0692- - -0110- -01-
APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
LEFT ONTO LESLIE CAMOBELL AVE. GO .5
MILES TURN LEFT ONTO MAIN ST GO 1.2
MILES AND THEN TURN RIGHT ONTO MITCHELL
RD APPROX 2 MILES ON RIGHT IS THE LOT.
ACROSS THE ROAD FROM THE POND.
DJOHNSON

065617

STRUCTURE: 000 000 53X80 4 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06 <u>8-4</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420 <u>KS</u>

COMMENTS AND NOTES

ADDRESS : : 85109 *UNASSIGNED SUBDIV:
CONTRACTOR : : PHONE :
OWNER . . : ADAMS ALEX & LEIGH PHONE : (919) 639-6884
PARCEL . . : 04-0692- - -0110- -01-
APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
LEFT ONTO LESLIE CAMOBELL AVE. GO .5
MILES TURN LEFT ONTO MAIN ST GO 1.2
MILES AND THEN TURN RIGHT ONTO MITCHELL
RD APPROX 2 MILES ON RIGHT IS THE LOT.
ACROSS THE ROAD FROM THE POND.
DJOHNSON

STRUCTURE: 000 000 53X80 4 BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867

8-28-06 APBS

----- COMMENTS AND NOTES -----

ADDRESS : 1676 MITCHELL RD
 CONTRACTOR :
 OWNER : ADAMS ALEX & LEIGH
 PARCEL : 04-0692- - -0110- -01-
 APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
 LEFT ONTO LESLIE CAMOBELL AVE. GO .5
 MILES TURN LEFT ONTO MAIN ST GO 1.2
 MILES AND THEN TURN RIGHT ONTO MITCHELL
 RD APPROX 2 MILES ON RIGHT IS THE LOT.
 ACROSS THE ROAD FROM THE POND.
 DJOHNSON

STRUCTURE: 000 000 53X80 4 BR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867
	8/28/06	AP	
A814 01	9/01/06	FB	ADDRESS CONFIRMATION VRU #: 001266683
	8/31/06	AP	1676 MITCHELL RD
B105 01	9/11/06	TI	R*OPEN FLOOR VRU #: 001270081

9-11 AP KS

COMMENTS AND NOTES

ADDRESS : 1676 MITCHELL RD
CONTRACTOR :
OWNER : ADAMS ALEX & LEIGH
PARCEL : 04-0692- - -0110- -01-
APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE : (919) 639-6884

DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
LEFT ONTO LESLIE CAMOBELL AVE. GO .5
MILES TURN LEFT ONTO MAIN ST GO 1.2
MILES AND THEN TURN RIGHT ONTO MITCHELL
RD APPROX 2 MILES ON RIGHT IS THE LOT.
ACROSS THE ROAD FROM THE POND.
DJOHNSON

STRUCTURE: 000 000 53X80 4 BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867
	8/28/06	AP	
A814 01	9/01/06	FB	ADDRESS CONFIRMATION VRU #: 001266683
	8/31/06	AP	1676 MITCHELL RD
B105 01	9/11/06	KS	R*OPEN FLOOR VRU #: 001270081
	9/11/06	AP	
R431 01	10/17/06	TI	FOUR TRADE FINAL >2500 VRU #: 001292606
	10/16/06	CA	
R427 01	10/17/06	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001293299
	<u>10-17</u>	<u>DA</u>	THIS WAS CALLED IN AS A 4-TRADE FINAL. I CHANGED TO ROUGH IN. -NJT

COMMENTS AND NOTES

897 4383

ADDRESS : 1676 MITCHELL RD
CONTRACTOR :
OWNER : ADAMS ALEX & LEIGH
PARCEL : 04-0692- - -0110- -01-
APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE :
PHONE : (919) 639-6884

DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
LEFT ONTO LESLIE CAMOBELL AVE. GO .5
MILES TURN LEFT ONTO MAIN ST GO 1.2
MILES AND THEN TURN RIGHT ONTO MITCHELL
RD APPROX 2 MILES ON RIGHT IS THE LOT.
ACROSS THE ROAD FROM THE POND.
DJOHNSON

STRUCTURE: 000 000 53X80 4 BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867
	8/28/06	AP	
A814 01	9/01/06	FB	ADDRESS CONFIRMATION VRU #: 001266683
	8/31/06	AP	1676 MITCHELL RD
B105 01	9/11/06	KS	R*OPEN FLOOR VRU #: 001270081
	9/11/06	AP	
R431 01	10/17/06	TI	FOUR TRADE FINAL >2500 VRU #: 001292606
	10/16/06	CA	
R427 01	10/17/06	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001293299
	10/17/06	DA	THIS WAS CALLED IN AS A 4-TRADE FINAL. I CHANGED TO ROUGH IN. -NJT 1. bath fans not installed 2. Need to plywood inside of garage wing walls
I129 01	11/01/06	TI	R*INSULATION INSPECTION VRU #: 001301555
R427 02	11/01/06	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001301837

11-1 AP
11-1 AP

KS

COMMENTS AND NOTES

ADDRESS : 1676 MITCHELL RD
 CONTRACTOR :
 OWNER : ADAMS ALEX & LEIGH
 PARCEL : 04-0692- - -0110- -01-
 APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
 LEFT ONTO LESLIE CAMOBELL AVE. GO .5
 MILES TURN LEFT ONTO MAIN ST GO 1.2
 MILES AND THEN TURN RIGHT ONTO MITCHELL
 RD APPROX 2 MILES ON RIGHT IS THE LOT.
 ACROSS THE ROAD FROM THE POND.
 DJOHNSON

SUBDIV:
 PHONE :
 PHONE : (919) 639-6884

STRUCTURE: 000 000 53X80 4 BR
 FLOOD ZONE . . . : FLOOD ZONE X

*Trash
 ?
 call
 had real
 windows*

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867
	8/28/06	AP	
A814 01	9/01/06	FB	ADDRESS CONFIRMATION VRU #: 001266683
	8/31/06	AP	✓1676 MITCHELL RD
B105 01	9/11/06	KS	R*OPEN FLOOR VRU #: 001270081
	9/11/06	AP	
R431 01	10/17/06	TI	FOUR TRADE FINAL >2500 VRU #: 001292606
	10/16/06	CA	
R427 01	10/17/06	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001293299
	10/17/06	DA	THIS WAS CALLED IN AS A 4-TRADE FINAL. I CHANGED TO ROUGH IN. -NJT 1. bath fans not installed 2. Need to plywood inside of garage wing walls
I129 01	11/01/06	KS	R*INSULATION INSPECTION VRU #: 001301555
	11/01/06	AP	
R427 02	11/01/06	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001301837
	11/01/06	AP	
H824 01	1/24/07	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001344225
	1/24/07	AP	
R431 02	2/22/07	TI	FOUR TRADE FINAL >2500 VRU #: 001358399

2-22 DA

ICS

COMMENTS AND NOTES

ADDRESS : 1676 MITCHELL RD
 CONTRACTOR :
 OWNER : ADAMS ALEX & LEIGH
 PARCEL : 04-0692- - -0110- -01-
 APPL NUMBER: 06-50015211 CP NEW RESIDENTIAL (SFD)

SUBDIV:
 PHONE :
 PHONE : (919) 639-6884

DIRECTIONS : TAKE RIGHT ONTO 421S GO 3.3 MILES TURN
 LEFT ONTO LESLIE CAMOBELL AVE. GO .5
 MILES TURN LEFT ONTO MAIN ST GO 1.2
 MILES AND THEN TURN RIGHT ONTO MITCHELL
 RD APPROX 2 MILES ON RIGHT IS THE LOT.
 ACROSS THE ROAD FROM THE POND.
 DJOHNSON

STRUCTURE: 000 000 53X80 4 BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/04/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001248420
	8/04/06	AP	
B103 01	8/28/06	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001263867
	8/28/06	AP	
A814 01	9/01/06	FB	ADDRESS CONFIRMATION VRU #: 001266683
	8/31/06	AP	1676 MITCHELL RD
B105 01	9/11/06	KS	R*OPEN FLOOR VRU #: 001270081
	9/11/06	AP	
R431 01	10/17/06	TI	FOUR TRADE FINAL >2500 VRU #: 001292606
	10/16/06	CA	
R427 01	10/17/06	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001293299
	10/17/06	DA	THIS WAS CALLED IN AS A 4-TRADE FINAL. I CHANGED TO ROUGH IN. -NJT
			1. bath fans not installed
			2. Need to plywood inside of garage wing walls
I129 01	11/01/06	KS	R*INSULATION INSPECTION VRU #: 001301555
	11/01/06	AP	
R427 02	11/01/06	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001301837
	11/01/06	AP	
H824 01	1/24/07	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001344225
	1/24/07	AP	
R431 02	2/22/07	KS	FOUR TRADE FINAL >2500 VRU #: 001358399
	2/22/07	DA	1. No 911 numbers on the house
			2. Handrail to 2nd floor shall be 30 to 38 inches from stair nosing. Yours is at 26.
			3. From winder to first stair to play room at 9 inches. Shall not be greater than 3/8ths of an inch variation to all other risers in the stairway. Max riser is 8 1/4"
			4. Caulk all toilets at floor
			5. Need attic access door
			6. Remove trash in crawl space and reinstall fallen insulation.
R431 03	2/23/07	BS	FOUR TRADE FINAL >2500 VRU #: 001359926
	2/23/07	CA	per phone call
R431 05	2/27/07	TI	FOUR TRADE FINAL >2500 VRU #: 001361203
R431 04	2/27/07	TI	FOUR TRADE FINAL >2500 VRU #: 001361195
	2/26/07	CA	

2-27 AP KS

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Alex Adams Electrical Permit No.: _____
Building Address: 1676 Mitchell Rd Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 2-27-07 Envir. C.O. No.: _____
Ken Slatt

06-5-15211

Building Official

Zoning Official