

HARNETT COUNTY HEALTH DEPARTMENT

HTE# 06-5-15273

# IMPROVEMENT PERMIT 23170

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) HAMPSON CUSTOM BUILDERS New Installation  Septic Tank  Repair

Property Location: SR# 1437 BALLARD RD Nitrification Line  Expansion

Subdivision BALLARD WOODS Lot # 65

Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 (360 gpd) Lot Size: .57 AC

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100 ft.

**Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.**

Type of system:  Conventional  Other PUMP TO 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 225 ft. width of ditches 3 ft. depth of ditches 24 in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 7/31/06  
**PERMIT EXPIRES 5 YEARS FROM ABOVE DATE**

**This permit is subject to revocation if site plans or intended use change.**

Signed: [Signature] RS (OLIVER TOLKSDORF)  
Environmental Health Specialist

\* FINAL SYSTEM LAYOUT TO BE DETERMINED AFTER LOT IS CLEARED



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 23170. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

HAMPTON CUSTOM BUILDERS 919-524-2915  
Name Telephone #

PO Box 655 HOLLY SPRINGS NC 27540  
Address

1437 BALLARD RD  
Property Location SR# Road Name

BALLARD Woods 65 3 (360 gpd) .57ac  
Subdivision Lot # # Bedrooms Proposed Lot Size

**TYPE OF SYSTEM**

New Installation [ ] Repair  Septic Tank  Nitrification Lines

[ ] Conventional  Other PUMP TO 25% REDUCTION SYSTEM

[ ] Basement [ ] With Plumbing [ ] Without Plumbing

Water Supply: [ ] Well  Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber 1000 gal

**NITRIFICATION FIELD SPECIFICATIONS**

Number of fields 1 # of lines per field 1 Length of lines 225 Ft.

Width of ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] ES  
Signature of Authorized Agent for Harnett County

7/31/06  
Date