

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method:

Auger Boring Pit

Cut

Type of Wastewater:

Sewage Industrial Process

Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				Profile Class & LTAR	
			1941 Structure/ Texture	1941 Consistence/ Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1945 Sapro Class	1944 Restr Hortz		
1	L 2-5%	0-27"	G SL	VFR SS/MP					PS .4	
		27-36"	SBK SCL	F1 SS/SP						
		P.15 36" DEEP								
2	L 2-5%	0-19"	G SL	VFR NS/MP					PS .4	
		19-40"	SBK SCL	F2 SS/SP						
		P.15 40" DEEP								
3	L 2-5%	0-42"	G SL	VFR NS/MP					PS .6	

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	PUMP INNOV	LPP
Site LTAR	.4	.4

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present: —